

CHAMUNDESHWAR ELECTRICITY SUPPLY CORPORATION

Estimate No HC-321 Date 17/11/2023
 (Estimate for Temporary power supply is an extent of 01 KW HP/KW for the)
 purpose of Building construction

..... for a period 60 Days of
 Sri/Smt. Sadashtta B.p. S/O Late puttasham
 - godce at Savasihale Village
 in Hagare O&M section Belga S/O

SL NO.	Particulars	Unit	Qty	Single phase	Three phase
1	Single phase/ 3 phase meter	No.	1	630.00	3920.00
2	RC cutout etc			70.00	80.00
3	Cost of the Labour			50.00	100.00
4	Employees cost at 20% on above			150.00	820.00
5	Transportation charges			25.00	25.00
6	Miscellaneous materials			75.00	80.00
7	Contingency at 5% on above			50.00	251.00
8	Total cost of the estimate			1050.00	5276.00
9	Service charges at 10% on item no 8			105.00	527.00
10	Cost of returnable materials credit	No.		630.00	3920.00
11	Net cost the estimate			525.00	1884.00


Certificate: Certified that I have inspected the spot personally and prepared the estimate as per the current schedule of rates for most economical and safe way of executing the work.

Report: The Transformer 63 KVA at DTC-435730 Savasihale
 can taken up this additional load of 01 KW for the purpose of Building
 Construction that load will be connected safely.
 Existing load - 10hp + 20KW

CHAMUNDESHWAR ELECTRICITY SUPPLY CORPORATION

Belga S/O

17/11/2023





[illegible]

16

2