

(ಕಂಪನಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

ಆವರಣದ ಮಾದರಿ
ಪಾಯಿಂಟು/ಮೋಟಾರುಗಳ ಒಟ್ಟು ಸಂಖ್ಯೆ
ಒಟ್ಟು ಸಂಪರ್ಕ ಪ್ರಮಾಣ
ಫೇಜ್ ಮೇಲೆ ಸಂಪರ್ಕ ಪ್ರಮಾಣ

ವಿತರಣಾ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರುಗಳು
ಇರುವ ಸ್ಥಳ
ವೈಲ್ಡ್ ಪ್ರಮಾಣ
ಸಾಮರ್ಥ್ಯ
ಸಂಪರ್ಕ ಪ್ರಮಾಣ

ಮಾಪಕ
ಮಾದರಿ ಮತ್ತು ತಯಾರಿಕೆ
ಸಾಮರ್ಥ್ಯ
ಪ್ರಾರಂಭದ ರಿಡಿಂಗ್

ಇತರೆ
ಮಾಪಕವನ್ನು ಸರಿಯಾಗಿ ಮೊಹರು ಮಾಡಿದೆಯೆ
ಮಾಪಕ ಟರ್ಮಿನಲ್ ಕವರನ್ನು ಮೊಹರು ಮಾಡಿದೆಯೆ
ಕಟ್‌ಜಾಟ್ ಮೊಹರು ಮಾಡಿದೆಯೆ
ಈ ಇನ್‌ಸ್ಟಲೇಷನ್ ವೈರಿಂಗ್
ನಿಯಮಗಳಿಗೆ ಅನುಸಾರವಾಗಿದೆಯೆ
ಯಾವುದಾದರೂ ನ್ಯೂನತೆಗಳನ್ನು ಗಮನಿಸಲಾಗಿದೆಯೆ
ಮಾಪಕ ಆವರ್ತವನ್ನು ಪರೀಕ್ಷಿಸಲಾಗಿದೆಯೆ?
ಸರಿಯಾಗಿದೆಯೆ ಮತ್ತು ಅದು
ಮಾಪಕ ಕಾರ್ಡನ್ನು ಹಾಕಿದೆಯೆ

LT3 ಆರ್.ಆರ್.ನಂ.ಬರೆಯಲಾಗಿದೆಯೇ?
01Kw ಮಾಪಕದಲ್ಲಿ ಹಾಳೆಯನ್ನು ಇಡಲಾಗಿದೆಯೇ?
2400 ಪುಸ್ತಕ ಸಂಖ್ಯೆ
..... ಇನ್‌ಸ್ಟಲೇಷನ್ ಸಂಖ್ಯೆ
..... ಸಂಪರ್ಕ ದಿನಾಂಕ
..... ಸಂಪರ್ಕ

11KV 1240V ಹೊಸ
5-30A-25KV4 ಟ್ಯಾಪಿಂಗ್
431D36 ದೂರವಾಣಿ ಕಾಸಿಂಗ್
..... ಯಾವ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ
..... ಈ ಆರ್. ಆರ್. ಸಂಖ್ಯೆ ನಂತರದ್ದು
..... ಮಾಪಕ ಓದುವ ದಿನಾಂಕ

EL-Sewedy ಸೇವಾ ಮಾರ್ಗ
5-30A ಕಂಟಕ್ಟರ್ ಸಿಯು/ಎ
00000.2 ಕೇಬಲ್ ಡಬ್ಬಿಂಗ್/ವಿವಿಆರ್/ಸಿಟಿಎಸ್
11031752 ಕೊಳವೆ

4.9 ಅರ್ಥಿಂಗ್
..... ಏರಿಯಲ್ ಫೈಸ್
..... ಕಟ್‌ಜಾಟ್
..... ಸಂಪರ್ಕ ಸೇವೆ ದೂರ

no ಪರೀಕ್ಷೆ
..... ಫೇಸುಗಳ ಮಧ್ಯೆ
..... ಫೇಸ್‌ನಿಂದ ನೆಲಕ್ಕೆ
..... ನ್ಯೂಟ್ರಲಿನಿಂದ ನೆಲಕ್ಕೆ

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ ನಾನು ಸ್ಥಾವರವನ್ನು ಪರೀಕ್ಷಿಸಿದ್ದೇನೆ.

A. H. M.

hamshakka B-S

(ಗ್ರಾಹಕರ ಸಹಿ)

ವಾಸದ ಮನೆ, ಅಂಗಡಿ, ಕಛೇರಿ, ಹೊಟೆಲು, ಫೈನ್‌ಡೆಸ್ಟ್, ಚಲ್ಲನೆಚ್ಚು ಮಂದಿರು, ಆಸ್ಪತ್ರೆ, ಫಾರ್ಮ್‌ಹೌಸ್, ಕೈಗಾರಿಕೆ (ಎವರಿಸಿ) ಕೃಷಿ ಪಂಪಿಂಗ್, ಇತರ
ಂಪಿಂಗ್, (ಎವರಿಸಿ) ಗೃಹ ಕೈಗಾರಿಕೆ, (ಎವರಿಸಿ), ಇದರಲ್ಲಿ ಯಾವುದು ಮೇಲುಭಾಗದ ಸಿಟಿಂಗ್.

ಕಛೇರಿ ಉಪಯೋಗಕ್ಕೆ ಮಾತ್ರ

ಇಂಜಿನಿಯರು

ಇಂಜಿನಿಯರು

BLH-49673
8-11-2023

new

SNKL-37010

8/m 9
per regularly

15mh

OK

ಹಾಢುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
HAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 25/6/23

is to Certify that the Meter received from **EL SEWEDY ELECTRO METER**
is tested good it is Sealed in the **MT** section having the Meter & Seal details
below.

er Details :

re: **EL SEWEDY**
e: **EM101-1**
s: **1**

1P,2 W
3200Imp/kWh
50 Hz.

240V
5-30A

er Sl.No. : 1103/752 Intital Reading 000 00.2 (CkWh)

Provided to Main Cover

EL

(EL-S White Plastic)

bered 1103/752 (CESC G & W Plastic)

CAL PORT: Numbered round (CESC G & W Plastic)

ET KHNb: Numbered round (CESC G & W Plastic)

Meenu
JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division



EL - Sewedy Electrometer India Pvt. Ltd.

TAX INVOICE

Head Office Address:
EL-Sewedy Electrometer India Pvt. Ltd.
Energy Meter Retail Outlet, MPL Compound, Shri Harsha Road,
O/o Executive Engineer CESC, N.R. Mohalla Division, MYSORE-570001
Branch Office Address:
EL-Sewedy Electro meter India Pvt. Ltd.
Energy Meter Retail Outlet, O/o Executive Engineer,
O&M Division, CESC, HN Pura Road, Near
KSRTC Bus stand, HASSAN - 573201.

Plot No.: C-138, Sector-63 Noida-201301 UP, INDIA
GSTIN NO.: 09AACCE0583H1ZO

Customer Name

Address

Chancha Shikha D.S.
B.A. Home Science
Ballone Hall.
Hassan Belu

BILL No.: HSN/23/ 3923

DATE: 28/08/27

GSTIN: 29AACCE0583H1ZM

GSTIN:

Description of Goods/ Service

HSN Code: 90283090 Single / Three Phase / LTCT Static Energy Meter

Sl. Nos.

11031752

Quantity (Nos.)	Rate Per Pc (Rs.)	Value Amount Rs.	P.
1	788-99	788 99	
/			
CGST@ 9%		71 01	
SGST@ 9%		71 01	
GRAND TOTAL		931 01	

ESC Division

IO. No. 23-17000

Date 28/8/27

Total Invoice Value (In Words):

MANUFACTURER'S WARRANTY

E.O.E 1st Copy Original 2nd Copy Duplicate 3rd Copy Triplicate

Whereas the EL-Sewedy Electrometer India Pvt. Ltd. meters sold by us are warranted against any manufacturing defects for a period of 3 (Five) Years from the date of sale, and that this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. However, shall not cover or extend to damage due to misuse/mishandling tampering/accident of negligence on part of the consumer, normal wear and tear of the meters mounted indoor. 2. The meters mounted indoor. 3. In case the meters are mounted outdoor, they are protected against direct exposure to sunlight and weather conditions in a proper way. 4. The meters maintained in a proper way. 5. The meters store in a dry and protected place. The meters will be warranted in accordance with the above warranty clause will not be applicable.

For EL-Sewedy Electrometer India Pvt. Ltd.