

Meter Details					
Make of Meter	L&T	Meter Version	NTD19.04	VinPlus Version	TS 232.01
Meter Serial No.	18153209	Meter Type	2,(3ph-4W) HT PT/CT	Meter Location	
Consumer Name		Consumer ID			
Anomaly	A0XXXXXXXXXX000	Collection			
Data Dump Time(PC)	03/10/2023 10:47:36	Data Read Time (Meter)	01/10/2023 13:13:38	Data Read Time (MRI/PC)	01/10/2023 16:16:24
CT Ratio	1	PT Ratio	1		
Association Mode	1,(Meter Reader)	Logical Device Name	LNTM4XXXXXXC5	Manufactured Info	2018
Name Plate Details	HT 63.5V CL 0.2(ACTIVE) 0.2(REACTIVE) Ib-1A				
Utility Name					
CT Rating	1-2A	Category	HT(PT/CT operated)<(CT operated)-C1		

Present Values

Cumulative Energies at		01/10/2023 13:14			
Power ON Time since Reset		0 Years, 0 Days, 11 Hrs, 4 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	118.32	108.13	--	--	--
2	319.62	290.73	--	--	--
3	130.22	117.84	--	--	--
4	17.75	15.03	--	--	--
5	0.00	0	--	--	--
6	0.00	0	--	--	--
7	0.00	0	--	--	--
8	0.00	0	--	--	--
Total	585.91	531.73	220.84	137.15	0.75



Cumulative MD(MAX of Tariffs)

Fwd.kVA	Fwd.kW
5.1200	4.5900

Consumption from 01/10/2023 00:00 to 01/10/2023 13:14					
Reset Mechanism					
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	0.08	0.06	--	--	--
2	0.04	0.03	--	--	--
3	0.00	0.00	--	--	--
4	0.00	0.00	--	--	--
5	0.00	0.00	--	--	--
6	0.00	0.00	--	--	--
7	0.00	0.00	--	--	--
8	0.00	0.00	--	--	--
Total	0.12	0.09	0.04	0.08	0.750

MD Parameter :

TOD	Fwd.kW	Fwd.kVA
1	0.0459	0.0501
TOD MD DateTime	01/10/2023 09:30	01/10/2023 09:30
2	0.0340	0.0386
TOD MD DateTime	01/10/2023 12:30	01/10/2023 12:30
3	0.0000	0.0000
4	0.0008	0.0008
TOD MD DateTime	01/10/2023 03:00	01/10/2023 03:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD (0-24hrs)	Fwd.kW	Fwd.kVA
Value	0.0459	0.0501
MD DateTime	01/10/2023 09:30	01/10/2023 09:30



Schneider Electric India Private Limited

Billing Report

Cumulative energies - Resetwise:

Cumulative energy at		01/10/2023 00:00		Reset No: 1	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 20 Hrs, 33 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	118.24	108.07	--	--	--
2	319.58	290.7	--	--	--
3	130.22	117.84	--	--	--
4	17.75	15.03	--	--	--
5	0	0	--	--	--
6	0	0	--	--	--
7	0	0	--	--	--
8	0	0	--	--	--
Total	585.79	531.64	220.8	137.07	0.92
Cumulative energy at		01/09/2023 00:00		Reset No: 2	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 13 Hrs, 27 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	117.64	107.49	--	--	--
2	315.88	287.3	--	--	--
3	129.54	117.22	--	--	--
4	17.57	14.85	--	--	--
5	0	0	--	--	--
6	0	0	--	--	--
7	0	0	--	--	--
8	0	0	--	--	--
Total	580.63	526.86	219.14	131.98	0.88

Cumulative energy at		01/08/2023 00:00			Reset No: 3	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 7 Hrs, 3 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	115.67	105.71	--	--		--
2	309.31	281.56	--	--		--
3	127.13	115.08	--	--		--
4	17.34	14.62	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	569.45	516.97	214.56	127.55		0.88
Cumulative energy at		01/07/2023 00:00			Reset No: 4	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 22 Hrs, 53 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	113.6	103.84	--	--		--
2	304.11	276.99	--	--		--
3	124.78	112.99	--	--		--
4	17.15	14.43	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	559.64	508.25	210.43	122.91		0.87

Cumulative energy at		01/06/2023 00:00			Reset No: 5	Reset Type:
Billing Power ON Time		0 Years, 26 Days, 23 Hrs, 9 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	111.72	102.18	--	--		--
2	298.62	272.21	--	--		--
3	123.28	111.71	--	--		--
4	16.91	14.19	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	550.53	500.29	206.6	118.44		0.9
Cumulative energy at		01/05/2023 00:00			Reset No: 6	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 23 Hrs, 17 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	109.82	100.45	--	--		--
2	293.55	267.64	--	--		--
3	121.09	109.7	--	--		--
4	16.72	14.01	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	541.18	491.8	203.15	114.31		0.9



Schneider Electric India Private Limited

Billing Report

Cumulative energy at		01/04/2023 00:00			Reset No: 7	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 23 Hrs, 41 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	107.52	98.36	--	--		--
2	288.86	263.41	--	--		--
3	117.95	106.88	--	--		--
4	16.53	13.81	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	530.86	482.46	199.21	110.06		0.86
Cumulative energy at		01/03/2023 00:00			Reset No: 8	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 10 Hrs, 3 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	105.73	96.8	--	--		--
2	283.56	258.84	--	--		--
3	115.24	104.5	--	--		--
4	16.3	13.6	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	520.83	473.74	194.79	105.4		0.88



Schneider Electric India Private Limited

Billing Report

Cumulative energy at		01/02/2023 00:00			Reset No: 9	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 16 Hrs, 4 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	104.1	95.33	--	--		--
2	277.68	253.67	--	--		--
3	114.05	103.45	--	--		--
4	16.11	13.4	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	511.94	465.85	191.13	100.95		0.86
Cumulative energy at		01/01/2023 00:00			Reset No: 10	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 2 Hrs, 55 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	101.7	93.23	--	--		--
2	271.93	248.71	--	--		--
3	112.13	101.77	--	--		--
4	15.79	13.11	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	501.55	456.82	186.5	96.01		0.87

Cumulative energy at		01/12/2022 00:00			Reset No: 11	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 23 Hrs, 8 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	99.36	91.15	--	--		--
2	267.09	244.55	--	--		--
3	109.51	99.43	--	--		--
4	14.96	12.35	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	490.92	447.48	181.87	91.18		0.87
Cumulative energy at		01/11/2022 00:00			Reset No: 12	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 4 Hrs, 53 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	96.29	88.39	--	--		--
2	259.35	237.86	--	--		--
3	106.94	97.14	--	--		--
4	14.78	12.17	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	477.36	435.56	176	87.01		0.84



Billing Report

Cumulative energy at		01/10/2022 00:00			Reset No: 13	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 1 Hrs, 54 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	94.51	86.79	--	--		--
2	251.15	231.07	--	--		--
3	104.26	94.83	--	--		--
4	14.49	11.88	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	464.41	424.57	169.77	82.56		0.93
Cumulative energy at		01/09/2022 00:00			Reset No: 14	Reset Type:
Billing Power ON Time		0 Years, 26 Days, 22 Hrs, 46 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	92.27	84.69	--	--		--
2	245.03	225.35	--	--		--
3	101.37	92.15	--	--		--
4	14.28	11.67	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	452.95	413.86	166.13	78.09		0.92

Cumulative energy at		01/08/2022 00:00			Reset No: 15	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 22 Hrs, 1 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	90.59	83.14	--	--		--
2	239.55	220.29	--	--		--
3	99.19	90.14	--	--		--
4	14.11	11.5	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	443.44	405.07	162.87	73.79		0.93
Cumulative energy at		01/07/2022 00:00			Reset No: 16	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 17 Hrs, 55 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	87.01	79.78	--	--		--
2	232.37	213.59	--	--		--
3	95.77	87	--	--		--
4	13.97	11.37	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	429.12	391.74	158.06	69.67		0.91

Cumulative energy at		01/06/2022 00:00			Reset No: 17	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 16 Hrs, 47 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	82.72	75.83	--	--		--
2	222.56	204.55	--	--		--
3	90.63	82.32	--	--		--
4	13.67	11.08	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	409.58	373.78	150.83	66.09		0.89
Cumulative energy at		01/05/2022 00:00			Reset No: 18	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 18 Hrs, 34 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	79.64	73.06	--	--		--
2	214.94	197.71	--	--		--
3	86.84	78.94	--	--		--
4	13.34	10.76	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	394.76	360.47	144.74	61.77		0.91

Cumulative energy at		01/04/2022 00:00			Reset No: 19	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 18 Hrs, 36 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	76.29	69.97	--	--		--
2	205.7	189.22	--	--		--
3	83.56	75.92	--	--		--
4	13.1	10.54	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	378.65	345.65	138.89	58.12		0.92
Cumulative energy at		01/03/2022 00:00			Reset No: 20	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 14 Hrs, 14 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	71.89	65.92	--	--		--
2	201.39	185.21	--	--		--
3	79.33	72.04	--	--		--
4	12.35	9.85	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	364.96	333.02	134.02	53.79		0.91

Cumulative energy at		01/02/2022 00:00			Reset No: 21	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 2 Hrs, 50 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	68.03	62.37	--	--		--
2	192.97	177.45	--	--		--
3	74.45	67.63	--	--		--
4	12.07	9.58	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	347.52	317.03	127.52	50.68		0.91
Cumulative energy at		01/01/2022 00:00			Reset No: 22	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 8 Hrs, 49 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	63.01	57.8	--	--		--
2	183.43	168.71	--	--		--
3	69.66	63.28	--	--		--
4	11.87	9.39	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	327.97	299.18	120.06	47.22		0.91

Cumulative energy at		01/12/2021 00:00			Reset No: 23	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 16 Hrs, 35 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	59.61	54.66	--	--		--
2	175.63	161.51	--	--		--
3	65.87	59.86	--	--		--
4	11.72	9.25	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	312.83	285.28	114.43	42.94		0.94
Cumulative energy at		01/11/2021 00:00			Reset No: 24	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 4 Hrs, 37 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	58.73	53.84	--	--		--
2	172.06	158.1	--	--		--
3	64.77	58.82	--	--		--
4	11.57	9.11	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	307.13	279.87	112.85	38.71		0.88

Consumption - Resetwise

Reset No		1				
Consumption from		01/09/2023 00:00 to 01/10/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	0.60	0.58	--	--	--	
2	3.70	3.40	--	--	--	
3	0.68	0.62	--	--	--	
4	0.18	0.18	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	5.16	4.78	1.66	5.09	0.920	
Reset No		2				
Consumption from		01/08/2023 00:00 to 01/09/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.97	1.78	--	--	--	
2	6.57	5.74	--	--	--	
3	2.41	2.14	--	--	--	
4	0.23	0.23	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	11.18	9.89	4.58	4.43	0.880	

Reset No		3				
Consumption from		01/07/2023 00:00 to 01/08/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	2.07	1.87	--	--	--	
2	5.20	4.57	--	--	--	
3	2.35	2.09	--	--	--	
4	0.19	0.19	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	9.81	8.72	4.13	4.64	0.880	
Reset No		4				
Consumption from		01/06/2023 00:00 to 01/07/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.88	1.66	--	--	--	
2	5.49	4.78	--	--	--	
3	1.50	1.28	--	--	--	
4	0.24	0.24	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	9.11	7.96	3.83	4.47	0.870	

Reset No		5				
Consumption from		01/05/2023 00:00 to 01/06/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.90	1.73	--	--	--	
2	5.07	4.57	--	--	--	
3	2.19	2.01	--	--	--	
4	0.19	0.18	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	9.35	8.49	3.45	4.13	0.900	
Reset No		6				
Consumption from		01/04/2023 00:00 to 01/05/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	2.30	2.09	--	--	--	
2	4.69	4.23	--	--	--	
3	3.14	2.82	--	--	--	
4	0.19	0.20	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	10.32	9.34	3.94	4.25	0.900	



Schneider Electric India Private Limited

Billing Report

Reset No		7				
Consumption from		01/03/2023 00:00 to 01/04/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.79	1.56	--	--	--	
2	5.30	4.57	--	--	--	
3	2.71	2.38	--	--	--	
4	0.23	0.21	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	10.03	8.72	4.42	4.66	0.860	
Reset No		8				
Consumption from		01/02/2023 00:00 to 01/03/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.63	1.47	--	--	--	
2	5.88	5.17	--	--	--	
3	1.19	1.05	--	--	--	
4	0.19	0.20	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	8.89	7.89	3.66	4.45	0.880	

Reset No		9				
Consumption from		01/01/2023 00:00 to 01/02/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	2.40	2.10	--	--	--	
2	5.75	4.96	--	--	--	
3	1.92	1.68	--	--	--	
4	0.32	0.29	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	10.39	9.03	4.63	4.94	0.860	
Reset No		10				
Consumption from		01/12/2022 00:00 to 01/01/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	2.34	2.08	--	--	--	
2	4.84	4.16	--	--	--	
3	2.62	2.34	--	--	--	
4	0.83	0.76	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	10.63	9.34	4.63	4.83	0.870	

Reset No		11				
Consumption from		01/11/2022 00:00 to 01/12/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.07	2.76	--	--	--	
2	7.74	6.69	--	--	--	
3	2.57	2.29	--	--	--	
4	0.18	0.18	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	13.56	11.92	5.87	4.17	0.870	
Reset No		12				
Consumption from		01/10/2022 00:00 to 01/11/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.78	1.60	--	--	--	
2	8.20	6.79	--	--	--	
3	2.68	2.31	--	--	--	
4	0.29	0.29	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	12.95	10.99	6.23	4.45	0.840	

Reset No		13				
Consumption from		01/09/2022 00:00 to 01/10/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	2.24	2.10	--	--	--	
2	6.12	5.72	--	--	--	
3	2.89	2.68	--	--	--	
4	0.21	0.21	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	11.46	10.71	3.64	4.47	0.930	
Reset No		14				
Consumption from		01/08/2022 00:00 to 01/09/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	1.68	1.55	--	--	--	
2	5.48	5.06	--	--	--	
3	2.18	2.01	--	--	--	
4	0.17	0.17	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	9.51	8.79	3.26	4.30	0.920	

Reset No		15				
Consumption from		01/07/2022 00:00 to 01/08/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.58	3.36	--	--	--	
2	7.18	6.70	--	--	--	
3	3.42	3.14	--	--	--	
4	0.14	0.13	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	14.32	13.33	4.81	4.12	0.930	
Reset No		16				
Consumption from		01/06/2022 00:00 to 01/07/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	4.29	3.95	--	--	--	
2	9.81	9.04	--	--	--	
3	5.14	4.68	--	--	--	
4	0.30	0.29	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	19.54	17.96	7.23	3.58	0.910	

Reset No		17				
Consumption from		01/05/2022 00:00 to 01/06/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.08	2.77	--	--	--	
2	7.62	6.84	--	--	--	
3	3.79	3.38	--	--	--	
4	0.33	0.32	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	14.82	13.31	6.09	4.32	0.890	
Reset No		18				
Consumption from		01/04/2022 00:00 to 01/05/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.35	3.09	--	--	--	
2	9.24	8.49	--	--	--	
3	3.28	3.02	--	--	--	
4	0.24	0.22	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	16.11	14.82	5.85	3.65	0.910	

Reset No		19				
Consumption from		01/03/2022 00:00 to 01/04/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	4.40	4.05	--	--	--	
2	4.31	4.01	--	--	--	
3	4.23	3.88	--	--	--	
4	0.75	0.69	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	13.69	12.63	4.87	4.33	0.920	
Reset No		20				
Consumption from		01/02/2022 00:00 to 01/03/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.86	3.55	--	--	--	
2	8.42	7.76	--	--	--	
3	4.88	4.41	--	--	--	
4	0.28	0.27	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	17.44	15.99	6.50	3.11	0.910	

Reset No		21				
Consumption from		01/01/2022 00:00 to 01/02/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.02	4.57	--	--	--	
2	9.54	8.74	--	--	--	
3	4.79	4.35	--	--	--	
4	0.20	0.19	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	19.55	17.85	7.46	3.46	0.910	
Reset No		22				
Consumption from		01/12/2021 00:00 to 01/01/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.40	3.14	--	--	--	
2	7.80	7.20	--	--	--	
3	3.79	3.42	--	--	--	
4	0.15	0.14	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	15.14	13.90	5.63	4.28	0.910	

Reset No		23				
Consumption from		01/11/2021 00:00 to 01/12/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	0.88	0.82	--	--	--	
2	3.57	3.41	--	--	--	
3	1.10	1.04	--	--	--	
4	0.15	0.14	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	5.70	5.41	1.58	4.23	0.940	

Maximum Demand (MD) - Resetwise

Reset No : 1		
MDTOD at	01/10/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0498	0.0542
TOD MD DateTime	02/09/2023 10:00	02/09/2023 10:00
2	0.0555	0.0613
TOD MD DateTime	01/09/2023 16:00	01/09/2023 16:00
3	0.0539	0.0596
TOD MD DateTime	01/09/2023 18:30	01/09/2023 18:30
4	0.0012	0.0012
TOD MD DateTime	14/09/2023 03:30	14/09/2023 03:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0555	0.0613
MD DateTime	01/09/2023 16:00	01/09/2023 16:00

Reset No : 2		
MDTOD at	01/09/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0814	0.0993
TOD MD DateTime	13/08/2023 10:00	13/08/2023 10:00
2	0.0854	0.1007
TOD MD DateTime	18/08/2023 17:30	11/08/2023 12:30
3	0.0738	0.0943
TOD MD DateTime	03/08/2023 18:30	03/08/2023 18:30
4	0.0226	0.0227
TOD MD DateTime	09/08/2023 06:00	09/08/2023 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0854	0.1007
MD DateTime	18/08/2023 17:30	11/08/2023 12:30



Schneider Electric India Private Limited

Billing Report

Reset No : 3		
MDTOD at	01/08/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0714	0.0914
TOD MD DateTime	16/07/2023 09:00	16/07/2023 09:30
2	0.0835	0.1000
TOD MD DateTime	02/07/2023 15:00	02/07/2023 15:00
3	0.0705	0.0802
TOD MD DateTime	07/07/2023 21:00	07/07/2023 21:00
4	0.0036	0.0046
TOD MD DateTime	24/07/2023 06:00	24/07/2023 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0835	0.1000
MD DateTime	02/07/2023 15:00	02/07/2023 15:00

Reset No : 4		
MDTOD at	01/07/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0708	0.0938
TOD MD DateTime	05/06/2023 07:00	05/06/2023 07:00
2	0.0804	0.1042
TOD MD DateTime	07/06/2023 16:00	06/06/2023 16:30
3	0.0655	0.0756
TOD MD DateTime	07/06/2023 21:00	07/06/2023 21:00
4	0.0322	0.0396
TOD MD DateTime	13/06/2023 06:00	13/06/2023 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0804	0.1042
MD DateTime	07/06/2023 16:00	06/06/2023 16:30

Reset No : 5		
MDTOD at	01/06/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0968	0.1178
TOD MD DateTime	08/05/2023 08:30	08/05/2023 08:30
2	0.0854	0.1019
TOD MD DateTime	05/05/2023 16:00	05/05/2023 16:00
3	0.0778	0.0878
TOD MD DateTime	10/05/2023 20:00	10/05/2023 20:00
4	0.0026	0.0026
TOD MD DateTime	04/05/2023 05:30	04/05/2023 05:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0968	0.1178
MD DateTime	08/05/2023 08:30	08/05/2023 08:30

Reset No : 6		
MDTOD at	01/05/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0750	0.0904
TOD MD DateTime	26/04/2023 07:00	26/04/2023 07:00
2	0.0759	0.0926
TOD MD DateTime	25/04/2023 11:30	22/04/2023 11:30
3	0.0687	0.0833
TOD MD DateTime	24/04/2023 21:30	24/04/2023 20:30
4	0.0032	0.0032
TOD MD DateTime	17/04/2023 22:30	17/04/2023 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0759	0.0926
MD DateTime	25/04/2023 11:30	22/04/2023 11:30

Reset No : 7		
MDTOD at	01/04/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0715	0.0851
TOD MD DateTime	12/03/2023 08:30	09/03/2023 09:00
2	0.0889	0.1080
TOD MD DateTime	18/03/2023 12:30	18/03/2023 12:30
3	0.0709	0.0926
TOD MD DateTime	09/03/2023 18:30	09/03/2023 18:30
4	0.0463	0.0525
TOD MD DateTime	11/03/2023 22:30	11/03/2023 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0889	0.1080
MD DateTime	18/03/2023 12:30	18/03/2023 12:30

Reset No : 8		
MDTOD at	01/03/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0708	0.0840
TOD MD DateTime	02/02/2023 09:30	16/02/2023 08:00
2	0.0901	0.1102
TOD MD DateTime	01/02/2023 16:00	17/02/2023 16:00
3	0.0739	0.0965
TOD MD DateTime	17/02/2023 18:30	17/02/2023 18:30
4	0.0465	0.0494
TOD MD DateTime	10/02/2023 06:00	10/02/2023 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0901	0.1102
MD DateTime	01/02/2023 16:00	17/02/2023 16:00

Reset No : 9		
MDTOD at	01/02/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0824	0.1044
TOD MD DateTime	14/01/2023 09:30	14/01/2023 09:30
2	0.1000	0.1173
TOD MD DateTime	19/01/2023 12:00	19/01/2023 12:00
3	0.0692	0.0745
TOD MD DateTime	30/01/2023 20:00	30/01/2023 20:00
4	0.0541	0.0654
TOD MD DateTime	12/01/2023 06:00	12/01/2023 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1000	0.1173
MD DateTime	19/01/2023 12:00	19/01/2023 12:00

Reset No : 10		
MDTOD at	01/01/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0767	0.0929
TOD MD DateTime	03/12/2022 08:00	03/12/2022 08:00
2	0.0763	0.0971
TOD MD DateTime	10/12/2022 12:30	10/12/2022 12:30
3	0.0742	0.0862
TOD MD DateTime	20/12/2022 19:30	01/12/2022 18:30
4	0.0758	0.0848
TOD MD DateTime	19/12/2022 05:30	19/12/2022 05:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0767	0.0971
MD DateTime	03/12/2022 08:00	10/12/2022 12:30

Reset No : 11		
MDTOD at	01/12/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0905	0.1103
TOD MD DateTime	08/11/2022 09:00	08/11/2022 09:00
2	0.1005	0.1210
TOD MD DateTime	08/11/2022 12:30	08/11/2022 12:30
3	0.0792	0.0911
TOD MD DateTime	07/11/2022 21:00	10/11/2022 18:30
4	0.0055	0.0058
TOD MD DateTime	16/11/2022 06:00	16/11/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1005	0.1210
MD DateTime	08/11/2022 12:30	08/11/2022 12:30

Reset No : 12		
MDTOD at	01/11/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0904	0.1084
TOD MD DateTime	28/10/2022 09:00	28/10/2022 09:00
2	0.0865	0.1043
TOD MD DateTime	17/10/2022 10:30	17/10/2022 13:00
3	0.0865	0.1033
TOD MD DateTime	01/10/2022 21:30	17/10/2022 19:00
4	0.0056	0.0056
TOD MD DateTime	20/10/2022 06:00	20/10/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0904	0.1084
MD DateTime	28/10/2022 09:00	28/10/2022 09:00

Reset No : 13		
MDTOD at	01/10/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0690	0.0740
TOD MD DateTime	07/09/2022 10:00	07/09/2022 10:00
2	0.0902	0.0962
TOD MD DateTime	09/09/2022 17:30	09/09/2022 17:30
3	0.0878	0.1031
TOD MD DateTime	30/09/2022 21:00	30/09/2022 21:00
4	0.0035	0.0038
TOD MD DateTime	15/09/2022 06:00	15/09/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0902	0.1031
MD DateTime	09/09/2022 17:30	30/09/2022 21:00

Reset No : 14		
MDTOD at	01/09/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0768	0.0838
TOD MD DateTime	14/08/2022 09:30	14/08/2022 09:30
2	0.0896	0.0954
TOD MD DateTime	28/08/2022 15:30	28/08/2022 15:30
3	0.0740	0.0794
TOD MD DateTime	23/08/2022 20:30	15/08/2022 21:00
4	0.0021	0.0021
TOD MD DateTime	13/08/2022 22:30	13/08/2022 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0896	0.0954
MD DateTime	28/08/2022 15:30	28/08/2022 15:30

Reset No : 15		
MDTOD at	01/08/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0948	0.1040
TOD MD DateTime	13/07/2022 10:00	13/07/2022 10:00
2	0.1013	0.1112
TOD MD DateTime	13/07/2022 12:00	13/07/2022 12:00
3	0.0998	0.1110
TOD MD DateTime	13/07/2022 21:30	13/07/2022 21:30
4	0.0047	0.0054
TOD MD DateTime	06/07/2022 06:00	06/07/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1013	0.1112
MD DateTime	13/07/2022 12:00	13/07/2022 12:00

Reset No : 16		
MDTOD at	01/07/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.1034	0.1136
TOD MD DateTime	25/06/2022 07:00	25/06/2022 07:00
2	0.1123	0.1237
TOD MD DateTime	14/06/2022 11:30	14/06/2022 11:30
3	0.1150	0.1263
TOD MD DateTime	14/06/2022 19:00	14/06/2022 19:00
4	0.0756	0.0827
TOD MD DateTime	26/06/2022 06:00	26/06/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1150	0.1263
MD DateTime	14/06/2022 19:00	14/06/2022 19:00

Reset No : 17		
MDTOD at	01/06/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.1035	0.1145
TOD MD DateTime	30/05/2022 07:30	30/05/2022 07:30
2	0.1127	0.1239
TOD MD DateTime	03/05/2022 11:30	03/05/2022 11:30
3	0.1020	0.1135
TOD MD DateTime	04/05/2022 19:30	04/05/2022 19:30
4	0.0528	0.0589
TOD MD DateTime	04/05/2022 06:00	04/05/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1127	0.1239
MD DateTime	03/05/2022 11:30	03/05/2022 11:30

Reset No : 18		
MDTOD at	01/05/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.1163	0.1293
TOD MD DateTime	30/04/2022 10:00	30/04/2022 10:00
2	0.1095	0.1193
TOD MD DateTime	14/04/2022 12:00	14/04/2022 12:00
3	0.1108	0.1209
TOD MD DateTime	27/04/2022 21:30	27/04/2022 21:30
4	0.0513	0.0602
TOD MD DateTime	20/04/2022 06:00	20/04/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1163	0.1293
MD DateTime	30/04/2022 10:00	30/04/2022 10:00

Reset No : 19		
MDTOD at	01/04/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.1138	0.1234
TOD MD DateTime	06/03/2022 08:00	06/03/2022 08:00
2	0.1125	0.1240
TOD MD DateTime	24/03/2022 18:00	24/03/2022 18:00
3	0.1076	0.1171
TOD MD DateTime	11/03/2022 21:30	11/03/2022 21:30
4	0.0955	0.1094
TOD MD DateTime	26/03/2022 05:30	26/03/2022 05:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1138	0.1240
MD DateTime	06/03/2022 08:00	24/03/2022 18:00

Reset No : 20		
MDTOD at	01/03/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0878	0.0968
TOD MD DateTime	24/02/2022 07:00	24/02/2022 07:00
2	0.1064	0.1149
TOD MD DateTime	15/02/2022 16:00	15/02/2022 16:00
3	0.1045	0.1144
TOD MD DateTime	15/02/2022 18:30	15/02/2022 18:30
4	0.0952	0.1043
TOD MD DateTime	09/02/2022 06:00	09/02/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1064	0.1149
MD DateTime	15/02/2022 16:00	15/02/2022 16:00

Reset No : 21		
MDTOD at	01/02/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0963	0.1053
TOD MD DateTime	30/01/2022 07:30	30/01/2022 07:30
2	0.1005	0.1103
TOD MD DateTime	29/01/2022 18:00	29/01/2022 18:00
3	0.1072	0.1177
TOD MD DateTime	29/01/2022 20:30	29/01/2022 20:30
4	0.0282	0.0286
TOD MD DateTime	25/01/2022 06:00	25/01/2022 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1072	0.1177
MD DateTime	29/01/2022 20:30	29/01/2022 20:30

Reset No : 22		
MDTOD at	01/01/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0908	0.0997
TOD MD DateTime	20/12/2021 09:00	20/12/2021 09:00
2	0.0935	0.1017
TOD MD DateTime	23/12/2021 12:30	23/12/2021 12:30
3	0.0874	0.0977
TOD MD DateTime	31/12/2021 20:00	31/12/2021 20:00
4	0.0033	0.0034
TOD MD DateTime	22/12/2021 22:30	22/12/2021 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0935	0.1017
MD DateTime	23/12/2021 12:30	23/12/2021 12:30

Reset No : 23		
MDTOD at	01/12/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0663	0.0727
TOD MD DateTime	01/11/2021 08:00	01/11/2021 08:00
2	0.0543	0.0571
TOD MD DateTime	25/11/2021 12:30	25/11/2021 12:30
3	0.0517	0.0552
TOD MD DateTime	08/11/2021 20:30	08/11/2021 20:30
4	0.0028	0.0028
TOD MD DateTime	07/11/2021 02:30	07/11/2021 02:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0663	0.0727
MD DateTime	01/11/2021 08:00	01/11/2021 08:00

Reset No : 24		
MDTOD at	01/11/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0811	0.0899
TOD MD DateTime	31/10/2021 07:30	31/10/2021 07:30
2	0.0882	0.0971
TOD MD DateTime	08/10/2021 18:00	08/10/2021 18:00
3	0.0779	0.0853
TOD MD DateTime	08/10/2021 20:00	08/10/2021 20:00
4	0.0097	0.0118
TOD MD DateTime	24/10/2021 06:00	24/10/2021 06:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0882	0.0971
MD DateTime	08/10/2021 18:00	08/10/2021 18:00

Cumulative MD (Max of Tariffs) - Resetwise

Reset No	Reset DateTime	Fwd.kVA	Fwd.kW
1	01/10/2023 00:00	5.1200	4.5900
2	01/09/2023 00:00	5.0600	4.5400
3	01/08/2023 00:00	4.9600	4.4500
4	01/07/2023 00:00	4.8600	4.3700
5	01/06/2023 00:00	4.7500	4.2900
6	01/05/2023 00:00	4.6400	4.1900
7	01/04/2023 00:00	4.5400	4.1100
8	01/03/2023 00:00	4.4400	4.0200
9	01/02/2023 00:00	4.3300	3.9300
10	01/01/2023 00:00	4.2100	3.8300
11	01/12/2022 00:00	4.1100	3.7600
12	01/11/2022 00:00	3.9900	3.6600
13	01/10/2022 00:00	3.8800	3.5700
14	01/09/2022 00:00	3.7800	3.4800
15	01/08/2022 00:00	3.6800	3.3900
16	01/07/2022 00:00	3.5700	3.2800
17	01/06/2022 00:00	3.4500	3.1700
18	01/05/2022 00:00	3.3200	3.0600
19	01/04/2022 00:00	3.1900	2.9400
20	01/03/2022 00:00	3.0700	2.8300
21	01/02/2022 00:00	2.9500	2.7200
22	01/01/2022 00:00	2.8400	2.6100
23	01/12/2021 00:00	2.7300	2.5200
24	01/11/2021 00:00	2.6600	2.4500

