


CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

Estimate No Ds A - 282 Date 29.11.2012
(Estimate for Temporary power supply is an extent of 110W HP/KW for the)
purpose of Building construction
..... for a period 28 Days of
Sri/Smt. Talaja n/o late B. Mayegowda
..... Indiranayana. Ahalali

SL NO.	Particulars	Unit	Qty	Single phase	Three phase
1	Single phase/ 3 phase meter	No.	1	630.00	3920.00
2	RC cutout etc			70.00	80.00
3	Cost of the Labour			50.00	100.00
4	Employees cost at 20% on above			150.00	820.00
5	Transportation charges			25.00	25.00
6	Miscellaneous materials			75.00	80.00
7	Contingency at 5% on above			50.00	251.00
8	Total costof the estimate			1050.00	5276.00
9	Service charges at 10%on item no 8			105.00	527.00
10	Cost of returnable materials credit	No.		630.00	3920.00
11	Net cost the estimate			525.00	1884.00

Certificate: Certified that I have inspected the spot personally and prepared the estimate as per the current schedule of rates for most economical and safe way of executing the work.

Report: The Transfomer 21KVA KVA at Indiranayana (436101)
can taken up this additional load of 110W KW for the purpose of Building
..... Construction that load will be connected safely.


..... (ವಿ)
ಕಾ. ಮತ್ತು ಪಾ. ಶಾಖೆ
ಸಹ್ಯ ಅರೇಹಳ್ಳಿ