

count ID	RR No	Spot Serial Tariff	DTC
413007838	YL2	1 LT2A(II)	435612
413002998	YL43	1 LT2A(II)	435612
413002997	YL61	1 LT2A(II)	435612
413013669	YL16	1 LT2A(II)	435612
451200100	YL44045	1 LT2A(II)	435612
413044467	YL40756	1 LT2A(II)	435612
413042795	YL39231	1 LT2A(II)	435612
413036184	YL34984	1 LT2A(II)	435612
413035935	YL34989	1 LT2A(II)	435612
413035263	YL34415	1 LT2A(II)	435612
413032944	YL32727	1 LT2A(II)	435612
413029095	YL25412	1 LT2A(II)	435612
413028943	YL25228	1 LT3(II)	435612
413028500	YL27239	1 LT3(II)	435612
413027941	YL11	1 LT2A(II)	435612
413026783	YL28559	1 LT3(II)	435612
413026404	YL4	1 LT2A(II)	435612
413026382	YLST1	1 LT6B	435612
413026252	YL24340	1 LT2A(II)	435612
413026251	YL24341	1 LT2A(II)	435612
413026235	YL110	1 LT2A(II)	435612
413026209	YL24375	1 LT2A(II)	435612
413025577	YL15	1 LT2A(II)	435612
C413024264	YL22485	1 LT2A(II)	435612
C413022755	YL6	1 LT2A(II)	435612
C413022648	YL22962	1 LT2A(II)	435612
C413022509	YL130	1 LT2A(II)	435612
C413022241	YL115	1 LT2A(II)	435612
C413021076	YLB35	1 LT1	435612
C413020643	YL21405	1 LT2A(II)	435612

Yalahanka. TC:-

25 KVA

DTC CODE:- 435612



[Signature]
 25 KVA TC
 435612

INDEX:-

	Existing 25 KVA TC
	Existing LT line
	Existing four line to proposed 5 wire
	Existing three line
	Existing two line to



CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

CESC.....BELUR.....SUB-DIVISION,

Estimate No.

HC-395

Date:

8/01/2024

Estimate for arranging Temporary Power Supply to an extent of 01 for Building

Construction Purpose for a period of 28 Days in favour of Sri/Smt.

H.L. Hemadatha

w/o Y.D. Kumar Swamy at Halahanka
Village in Hagare section Belur SD

In O & M

CSD, Hassan

Sl No.	Particulars	Unit	Qty	Single Phase	Three Phase
1.	Single Phase / Three Phase	Nos	1	1000.00	3920.00
2.	P.C. Cutout etc.,	Set	1	70.00	80.00
3.	Miscellaneous Materials			80.00	100.00
4.	Cost of the Labour			50.00	100.00
5.	Employees cost @ 20% on above			20.00	40.00
6.	Contingency @ 5% on above			24.00	84.00
7.	Transportation Charges			200.00	200.00
8.	Total Cost of the estimate			1444.00	4524.00
9.	Service charges at 10% on Item No. 8			144.00	452.00
10.	Cost of the returnable materials (Energy Meter)	Nos	1	1000.00	3920.00
11.	Net cost of the estimate			588.40	1056.00

Certificate : Certified that I have personally inspected the spot and prepared the estimate as Per current SR for safe and economical way of executing the work

Yalahanka

435612

Report

The Transformer of Capacity

25

KVA, at

01 HP/KW

DTC Code 435612 can taken up this additional load of

Safely.

Asst Engineer
O & M BELUR

Hagare

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸ. ನಿ. ನಿ., ಬೆಲೂರು

ಇಂಜಿನಿಯರ್

ಅಧೀನ

ಸಹಾಯಕ

ಅಧೀನ

ಅಧೀನ