



CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

NO: AEE/AET/CH -NAGAR/2022-23/272^(A) DT: 11/05/2022

OFFICE OF
The Assistant Executive Engineer (E I)
Chamaraja nagar Sub division, CESCO
Dated: 01-05-2022

OFFICIAL MEMORANUM

Sub: Reduction of load in respect of RR NO- CHT-60

Ref:(1) Application No: Dated: 01-05-2022

(2) Field report of O&M Section officer: Dated: 01-05-2022

Approval is hereby accorded for reduction of sanctioned load on RR NO CHT-60 under HT-2A tariff as per request of SRI M.P CHAYAKUMAR S/O M.S PUTTABUDDI at MUTTIGE village and field report of Junior Engineer, O&M Badanaguppe Section with the below details:

1)Load Details:

1	Existing Sanctioned load	600KVA
2	Reduction Sanctioned load	190KVA
3	Total Sanctioned load after load reduction	410KVA

NOTE: Old CT coils of ratio 30/1 to be replace new CT coils with ratio 25/1 at the time of HT rating and load reduction will be effected only after obtaining detailed HT rating report.

2)Consumer has submitted completion cum test report from Govt..Licensed Electrical Contractor and fresh power supply agreement for the Reduction load.

3)Load Reduction will get effective from 3 months after date of approval.

Assistant Executive Engineer (EL)
Chamarajanagar Urban sub-
Division, CESCO