

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 16/01/23

This is to Certify that the Meter received from M/s Landis+Gyr was tested good it is Sealed in the MT section having the Meter & Seal details as below.

Meter Details :

Meter : L&G 1P,2 W 240V (L-N)
Type : LGC110 3200 Imp/kwh 5-30A
E150
C : 1.0 50 Hz.

1

Initial Reading 000002 (CkWh)

Provided to Main Cover :

1. Red Plastic)
2. Numbered (CESC G & W Plastic)
3. METRIC PORT: Numbered round (CESC G & W Plastic)
4. MET KHN: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 16/01/23

This is to Certify that the Meter received from M/s Landis+Gyr was tested good it is Sealed in the MT section having the Meter & Seal details as below.

Meter Details :

Meter : L&G 1P,2 W 240V (L-N)
Type : LGC110 3200 Imp/kwh 5-30A
E150
C : 1.0 50 Hz.

2

Initial Reading 000002 (CkWh)

Provided to Main Cover :

1. Red Plastic)
2. Numbered (CESC G & W Plastic)
3. METRIC PORT: Numbered round (CESC G & W Plastic)
4. MET KHN: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division

ಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
SHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 16/3/23

to certify that the Meter received from M/s Landis+Gyr was tested good it
in the MT section having the Meter & Seal details as below.

S : 1P,2 W 240V (L-N)
110 3200 Imp/kwh 5-30A
0 50 Hz.

(3)

Initial Reading 00000-2 (CkWh)

ded to Main Cover :

Plastic)

(CESC G & W Plastic)

PORT: Numbered round (CESC G & W Plastic)

HNB: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division

ಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
UNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 16/3/23

to Certify that the Meter received from M/s Landis+Gyr was tested good it
in the MT section having the Meter & Seal details as below.

Details :
L&G 1P,2 W 240V (L-N)
LGC110 3200 Imp/kwh 5-30A
E150
s: 1.0 50 Hz.

(4)

Initial Reading 00000-2 (CkWh)

Provided to Main Cover :

&G Red Plastic)

(CESC G & W Plastic)

OPTICAL PORT: Numbered round (CESC G & W Plastic)

RESET KHNB: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division