

ಕಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
KAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 31-8-23

is to Certify that the Meter received from EL SEWEDY ELECTRO METER
LA Pvt. Ltd. was tested good it is Sealed in the MT section having the Meter
eal details as below.

Details :

EL SEWEDY	1P,2 W	240V
EM101-1	3200Imp/kWh	5-30A
S: 1	50 Hz.	

Sl.No. : 11024828 Initial Reading 000 001 (CkWh)


Provided to Main Cover

69452 - 06245 (EL-S White Plastic)

Numbered Re A526159 (CESC G & W Plastic)

CAL PORT: Numbered round (CESC G & W Plastic)

ET KHNB: Numbered round (CESC G & W Plastic)


JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division
Chamarajanagar