

Temporary power Supply (ಮಂಡಳಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

* ಆವರಣದ ಮಾದರಿ
ಪಾಯಿಂಟು/ಮೊಟಾರುಗಳ ಒಟ್ಟು ಸಂಖ್ಯೆ
ಒಟ್ಟು ಸಂಪರ್ಕ ಪ್ರಮಾಣ
ಪೇಜ್ ಮೇಲೆ ಸಂಪರ್ಕ ಪ್ರಮಾಣ ಅ)
ಆ)
ಇ)

LT ಆರ್.ಆರ್.ನಂ. ಬರೆಯಲಾಗಿದೆಯೆ
1KW ಮಾಪಕದಲ್ಲಿ ಹಾಳೆಯನ್ನು ಇಡಲಾಗಿದೆಯೇ
ಪುಸ್ತಕ ಸಂಖ್ಯೆ
ಇನ್‌ಸ್ಟಲೇಷನ್ ಸಂಖ್ಯೆ
ಸಂಪರ್ಕ ದಿನಾಂಕ

1/HTTPS-11/19/23
HTTPS-219
06/11/2023

ವಿತರಣಾ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರುಗಳು :
ಇರುವ ಸ್ಥಳ
ಪೊಲ್ಟೀಜ್ ಪ್ರಮಾಣ
ಸಾಮರ್ಥ್ಯ
ಸಂಪರ್ಕ ಪ್ರಮಾಣ

100 KVA
11KV 14330 ದೂರವಾಣಿ ಕ್ರಾಸಿಂಗ್

ಸಂಪರ್ಕ
ಹೂಸ
ಟ್ಯಾಪಿಂಗ್

ಮಾಪಕ :
ಮಾದರಿ ಮತ್ತು ತಯಾರಿಕೆ
ಸಾಮರ್ಥ್ಯ
ಪ್ರಾರಂಭದ ರೀಡಿಂಗ್

DT-435402 ಯಾವ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ
EL-Schwedy . 5.30A ಈ ಆರ್.ಆರ್. ಸಂಖ್ಯೆಯ ನಂತರದ್ದು
110 39320 ಮಾಪಕ ಓದುವ ದಿನಾಂಕ
IR-00000.9 ಸೇವಾ ಮಾರ್ಗ
ಕೇಬಲ್ ಡಬ್ಲ್ಯೂಪಿ/ವಿಐಆರ್/ಸಿಟಿಎನ್

HL-39001

ಇತರೆ :
ಮಾಪಕವನ್ನು ಸರಿಯಾಗಿ ಮೊಹರು ಮಾಡಿದೆಯೆ
ಮಾಪಕ ಟರ್ಮಿನಲ್ ಕವರನ್ನು ಮೊಹರು ಮಾಡಿದೆಯೆ
ಕಟ್ ಔಟ್ ಮೊಹರು ಮಾಡಿದೆಯೆ
ಈ ಇನ್‌ಸ್ಟಲೇಷನ್ ವೈರಿಂಗ್
ನಿಯಮಗಳಿಗೆ ಅನುಸಾರವಾಗಿದೆಯೆ
ಯಾವುದಾದರೂ ನ್ಯೂನತೆಗಳನ್ನು ಗಮನಿಸಲಾಗಿಯೆ
ಮಾಪಕ ಅವರ್ತವನ್ನು ಪರೀಕ್ಷಿಸಲಾಗಿದೆಯೆ
ಸರಿಯಾಗಿದೆಯೆ ಮತ್ತು ಅದು
ಮಾಪಕ ಕಾರ್ಡ್‌ನ್ನು ಹಾಕಿದೆಯೆ

ಕೊಳವೆ
ಅರ್ಥಿಂಗ್
ವಿರಿಯಲ್ ಫ್ಲೂಯಿಡ್
ಕಟ್ ಔಟ್
ಸಂಪರ್ಕ ಸೇವೆ ದೂರ
ಪರೀಕ್ಷೆ :
ಫೇಸುಗಳು ಮಧ್ಯೆ
ಫೇಸ್‌ನಿಂದ ನೆಲಕ್ಕೆ
ನ್ಯೂಟ್ರಲ್‌ನಿಂದ ನೆಲಕ್ಕೆ

TPS
1h
15mW

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ, ನಾನು ಸ್ಥಾವರವನ್ನು ಪರೀಕ್ಷಿಸಿದ್ದೇನೆ ಮತ್ತು ರೇಟಿಡ್ ಮಾಡಿದ್ದೇನೆ

ಗ್ರಾಹಕರ ಸಹಿ

ಲಾಂಚರ್
(ಗುತ್ತಿಗೆದಾರರ/ತಾಂತ್ರಿಕ ಸಲಹೆಗಾರರ ಸಹಿ)

ಇಂಜಿನಿಯರು

ವಾಸದ ಮನೆ, ಅಂಗಡಿ, ಕಛೇರಿ, ಹೋಟೆಲು, ರೆಸ್ಟೋರೆಂಟ್, ಚಲನಚಿತ್ರ, ಮಂದಿರ, ಆಸ್ಪತ್ರೆ, ಧಾರ್ಮಿಕ, ಶೈಕ್ಷಣಿಕ, ಕೈಗಾರಿಕೆ, (ವಿವರಿಸಿ) ಕೃಷಿ
, ಪಿಂಗ್, ಇತರ ಪಂಪಿಂಗ್, (ವಿವರಿಸಿ) ಗೃಹ ಕೈಗಾರಿಕೆ, (ವಿವರಿಸಿ) ಇದರಲ್ಲಿ ಯಾವುದು ಎಂಬುದನ್ನು ತಿಳಿಸಿ.

ಕಚೇರಿ ಉಪಯೋಗಕ್ಕೆ ಮಾತ್ರ

ಬಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ

BUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 15/9/23

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER** was tested good it is Sealed in the **MT** section having the Meter & Seal details as below.


Meter Details :

Make : **EL SEWEDY** 1P,2 W 240V
Type : EM101-1 3200Imp/kWh 5-30A
Class: 1 50 Hz.

Meter Sl.No. : 11039320 Initial Reading 00000.2 (CkWh)

Seal Provided to Main Cover

- 1) (EL-S White Plastic)
- 2) Numbered (CESC G & W Plastic)
- 3) OPTICAL PORT: Numbered round (CESC G & W Plastic)
- 4) RESET KHNB: Numbered round (CESC G & W Plastic)


JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division



TAX INVOICE

EL - Sewedy Electrometer India Pvt. Ltd.

Address.

Sewedy Electro meter India Pvt. Ltd.
Meter Retail Outlet, MPL Compound, Shri Harsha Road,
Executive Engineer CESC, N.R.Mohalla Division, MYSORE-570001
Sewedy Electrometer India Pvt. Ltd.
No: C-138, Sector-63 Noida-201301 UP, INDIA
PIN NO.: 09AACCE0583H1ZO

Branch Office Address .

EL-Sewedy Electro meter India Pvt. Ltd.
Energy Meter Retail Outlet, O/o Executive Engineer,
O&M Division, CESC, HN Pura Road, Near
KSRTC Bus stand, HASSAN - 573201

Customer Name: Sameyanda
Address: S/o Venkatesh
Hassan
Belm.

BILL No.: HSN/23/ 4459
DATE: 4/10/23.
GSTIN: 29AACCE0583H1ZM

Description of Goods/ Service	Quantity (Nos.)	Rate Per Pc (Rs.)	Value Amount	
			Rs.	P.
HSN Code : 90283090 Single / Three Phase / LTCT Static Energy Meter SI. Nos. 11039320	1	78899	78899	

CGST Division: Hassan
No: SJ-15148 Date: 3/10/23
Invoice Value (In Words):

CGST@ 9%	71 01
SGST@ 9%	71 01
GRAND TOTAL	931 01

FACTURER'S WARRANTY
E & O E 1st Copy Original 2nd Copy Duplicate 3rd Copy Triplicate
The EL-Sewedy Electrometer India Pvt. Ltd. meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) Years from the date of purchase. In the event of any defect for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge.

For EL-Sewedy Electrometer India Pvt. Ltd.