

ಕಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
KAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : ...20.11.2020...

is is to Certify that the Meter received from **EL SEWEDY ELECTRO METER**
DIA Pvt. Ltd. was tested good it is Sealed in the MT section having the Meter
Seal details as below.

Meter Details :

Make : **EL SEWEDY**

3P,4 W

3X240V/415V (L-N)

Type : **EM341-2**

1600Imp/kWh

5-30A

Class: **1.0**

50 Hz.

Meter Sl.No. : **EL-S-14177** Initial Reading 000 0.1 (CkWh)

Seal Provided to Main Cover

A 151044 (EL-S White Plastic)

Numbered R 100 652030 (CESC G & W Plastic)

OPTICAL PORT: Numbered round (CESC G & W Plastic)

RESET KHN: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg. (E)
LT Rating Sub-division

MBIP-SC115