

ಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ MUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

~~SEAL TRANS~~ ೨೨೮೨ TEST CERTIFICATE

Date: 29/12/23

to Certify that the Meter received from M/s Linkwell Telesystems was tested good it is Sealed
MT section having the Meter & Seal details as below.

Details :

: Linkwell Telesystems	1P, 2W	240V (L-N)	5-30A
: 36SM	3200 Imp/kWh	50 Hz	Class: 1.0

: 12153005 Initial Reading 00001.2 (C kWh)

Provided to Main Cover :

Linkwell Transparency) 1220705
Numbered REA 0715109 (CESC G & W Plastic)

OPTICAL PORT: Numbered round (CESC G & W Plastic)

REST KHNb: Numbered round (CESC G & W Plastic)

Sammya B
JE/AE/Asst. Executive Engg. (Ele.),
LT Rating Sub-division

MANDYA