

ಹಿಂದೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ  
HINDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

**TEST CERTIFICATE**

Date : 18/11/23

Certify that the Meter received from **EL SEWEDY ELECTRO METER** Ltd. was tested good it is Sealed in the **MT** section having the Meter details as below.

Details :

EL SEWEDY 1P,2 W 240V  
101-1 3200Imp/kWh 5-30A  
50 Hz.

11052830 Initial Reading 000 (CkWh)

Mounted to Main Cover

123245 (EL-S White Plastic)

10657530 (CESC G & W Plastic)

MT: Numbered round (CESC G & W Plastic)

MT: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),  
LT Rating Sub-division

Division

No. 35-16786 Date 18/11/23

Invoice Value (In Words) :

CGST@ 9%

SGST@ 9%

GRAND TOTAL

**MANUFACTURER'S WARRANTY**

E & O.E 1<sup>st</sup> Copy Original : 2<sup>nd</sup> Copy Duplicate : 3<sup>rd</sup> Copy Triplicate :

For EL-Sewedy Electrometer India Pvt. Ltd. meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) Years from the date of purchase. Within this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. However, shall not cover or extend to damage due to misuse/mishandling tampering/accident or negligence on part of the consumer, normal wear and tear or accident or negligence on part of the consumer, normal wear and tear of the moving parts and burnt meters of which shall be sole judge. the warranty is valid only if the meters are installed correctly. 2. the Meters mounted indoor. 3. in case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain. 4. the meters maintained in a proper way. 5. The meters maintained in a proper way. 6. the meters store in a dry and protected place. The meters will be supplied in sealed condition. Our above warranty clause will not be applicable once the factory seal/CESCO MT seal is broken/ tampered.

For EL-Sewedy Electrometer India Pvt. Ltd.

Signatory