

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 21/6/20

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER INDIA Pvt. Ltd.** was tested good it is Sealed in the **MT** section having the Meter & Seal details as below.

Meter Details :

Make : **EL SEWEDY**

1P,2 W

240V

Type : **EM101-1**

3200Imp/kWh

5-30A


Class: 1

50 Hz.

Meter Sl.No. : 11047625 Initial Reading 000002 (CkWh)

Seal Provided to Main Cover

- 1) (EL-S White Plastic)
- 2) Numbered (CESC G & W Plastic)
- 3) OPTICAL PORT: Numbered round (CESC G & W Plastic)
- 4) RESET KHNB: Numbered round (CESC G & W Plastic)


JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division

2