

256

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 21/10/23

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER** was tested good it is Sealed in the **MT** section having the Meter & Seal details as below.

Meter Details :

Make : **EL SEWEDY** 1P,2 W 240V
Type : **EM101-1** 3200Imp/kWh 5-30A
Class: **1** 50 Hz.

Meter SI.No. : 11047759 Initial Reading 000 00 02 (CkWh)
Seal Provided to Main Cover

- 1) (EL-S White Plastic)
- 2) Numbered (CESC G & W Plastic)
- 3) OPTICAL PORT: Numbered round (CESC G & W Plastic)
- 4) RESET KHNB: Numbered round (CESC G & W Plastic)

Deenab
JE/AE/Asst. Executive Engg.(Ele.),
LT Rating Sub-division

