

Temporary power supply

(ಕಂಪನಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

ಆವರಣದ ಮಾದರಿ

ಪಾಯಿಂಟು/ಮೋಟಾರುಗಳ ಒಟ್ಟು ಸಂಖ್ಯೆ

ಒಟ್ಟು ಸಂಪರ್ಕ ಪುಮಾಣ

ಫೇಜ್ ಮೇಲೆ ಸಂಪರ್ಕ ಪುಮಾಣ

ಅ)

ಆ)

ಇ)

ವಿವರಣಾ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರುಗಳು

ಇರುವ ಸ್ಥಳ

ಗ್ರಿಡ್‌ಲೈನ್ ಪುಮಾಣ

ಸಾಮರ್ಥ್ಯ

ಸಂಪರ್ಕ ಪುಮಾಣ

ಮಾಪಕ

ಮಾದರಿ ಮತ್ತು ತಯಾರಿಕೆ

ಸಾಮರ್ಥ್ಯ

ಪ್ರಾರಂಭದ ರಿಡೀಂಗ್

ಇತರೆ

ಮಾಪಕವನ್ನು ಸರಿಯಾಗಿ ಮೊಹರು ಮಾಡಿದೆಯೆ

ಮಾಪಕ ಟರ್ಮಿನಲ್ ಕವರನ್ನು ಮೊಹರು ಮಾಡಿದೆಯೆ

ಕಟ್‌ಜಾಟ್ ಮೊಹರು ಮಾಡಿದೆಯೆ

ಈ ಇನ್‌ಸ್ಟಲೇಷನ್ ವೈರಿಂಗ್

ನಿಯಮಗಳಿಗೆ ಅನುಸಾರವಾಗಿದೆಯೆ

ಯಾವುದಾದರೂ ನ್ಯೂನತೆಗಳನ್ನು ಗಮನಿಸಲಾಗಿದೆಯೆ

ಮಾಪಕ ಅವರ್ತವನ್ನು ಪರೀಕ್ಷಿಸಲಾಗಿದೆಯೆ?

ಸರಿಯಾಗಿದೆಯೆ ಮತ್ತು ಅದು

ಮಾಪಕ ಕಾರ್ಡ್‌ನ್ನು ಹಾಕಿದೆಯೆ

ಆರ್.ಆರ್.ನಂ.ಬರೆಯಲಾಗಿದೆಯೇ?

ಮಾಪಕದಲ್ಲಿ ಹಾಳೆಯನ್ನು ಇಡಲಾಗಿದೆಯೇ?

ಪುಸ್ತಕ ಸಂಖ್ಯೆ

ಇನ್‌ಸ್ಟಲೇಷನ್ ಸಂಖ್ಯೆ

ಸಂಪರ್ಕ ದಿನಾಂಕ

ಸಂಪರ್ಕ

ಹೊಸ

ಟ್ಯಾಪಿಂಗ್

ದೂರವಾಣಿ ಕ್ಯಾಪಿಂಗ್

ಯಾವ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ

ಈ ಆರ್. ಆರ್. ಸಂಖ್ಯೆ ನಂತರದ್ದು

ಮಾಪಕ ಓದುವ ದಿನಾಂಕ

ಸೇವಾ ಮಾರ್ಗ

ಕಂಟ್ರಾಕ್ಟ್ ಸಿಯು/ಎ

ಕೇಬಲ್ ಡಬ್ಲ್ಯೂಪಿ/ವಿಐಆರ್/ಸಿಟಿಎನ್

ಕೊಳವೆ

ಅರ್ಥಿಂಗ್

ವಿರಿಯಲ್ ಪೂಸ್

ಕಟ್‌ಜಾಟ್

ಸಂಪರ್ಕ ಸೇವೆ ದೂರ

ಪರೀಕ್ಷೆ

ಫೇಸುಗಳ ಮಧ್ಯೆ

ಫೇಸ್‌ನಿಂದ ನೆಲಕ್ಕೆ

ನ್ಯೂಟ್ರಲ್‌ನಿಂದ ನೆಲಕ್ಕೆ

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ, ನಾನು ಸ್ಥಾವರವನ್ನು ಪರೀಕ್ಷಿಸಿದ್ದೇನೆ.

408

HTPS-203
25/02/2023

HTPS

MLL-45

Temporary

power

Supply

15mh

Nettnaesthi G.M.

(ಗುತ್ತಿಗೆದಾರರ/ತಾಂತ್ರಿಕ ಸಲಹೆಗಾರರ ಸಹಿ)

ಇಂಜಿನಿಯರು

ವಾಸದ ಮನೆ, ಅಂಗಡಿ, ಕಛೇರಿ, ಹೊಟೆಲು, ರೆಸ್ಟೋರಂಟ್, ಚಲನಚಿತ್ರ ಮಂದಿರ, ಆಸ್ಪತ್ರೆ, ಧಾರ್ಮಿಕ, ಶೈಕ್ಷಣಿಕ, ಕೈಗಾರಿಕೆ (ವಿವರಿಸಿ) ಕೃಷಿ ಪಂಪಿಂಗ್, ಇತರ ಪಂಪಿಂಗ್, (ವಿವರಿಸಿ) ಗೃಹ ಕೈಗಾರಿಕೆ, (ವಿವರಿಸಿ), ಇದರಲ್ಲಿ ಯಾವುದು ಎಂಬುದನ್ನು ತಿಳಿಸಿರಿ.

ಕಛೇರಿ ಉಪಯೋಗಕ್ಕೆ ಮಾತ್ರ

ಮಂಡೂರಾತಿ ಸಂಖ್ಯೆ

ಖಾತೆ ಪುಸ್ತಕ ಪುಟ ಸಂಖ್ಯೆ

ಖಾತೆ ಸಂಖ್ಯೆ

ಕಾರ್ಯ ಆದೇಶ ಸಂಖ್ಯೆ ಮತ್ತು ದಿನಾಂಕ

ಇನ್‌ಸ್ಟಲೇಷನ್

ಹುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
HUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 21/02/23

To Certify that the Meter received from M/s Landis+Gyr was tested good it
is in the MT section having the Meter & Seal details as below.

Details :

L&G
LGC110
E150
1.0

1P,2 W
3200 Imp/kwh

240V (L-N)
5-30A

50 Hz.

..... C10721107 Intital Reading 00000.2 (CkWh)


Provided to Main Cover :

3 Red Plastic)

..... 84255527 (CESC G & W Plastic)

ICAL PORT: Numbered round (CESC G & W Plastic)

ET KHIN: Numbered round (CESC G & W Plastic)


JE/AE/Asst. Executive Engg. (Ele.),
LT Rating Sub-division

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್ + ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis + Gyr

1st Floor, 3rd Main,
ad, Hanumanthnagar,
RU - 560050.
8678515

Branch Office Address :
Old Executive Engineer, Q&A Division,
CESCO, HN Pura Road, Near VESITC, Bus Stand,
HASSAN - 573201.

Customer Name : M. M. Dinach Kumar
P.O. Malleshwara
andhara Hills,
Dahur

BILL No. HSN/22/ 07406

DATE: 23/02/23 TIME: 11:00 AM

GSTIN : 29AAACV972B1ZA

Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.
HSN Code : 90283010 Single / Three Phase / LTCT Static Energy Meter Model : E150 / E250 / E650, 5-30 Amps / -/5 Amps Serial Nos. <u>90721107</u>	1	529	529
CGST @ 9%			51.61
SGST @ 9%			51.61
GRAND TOTAL			632.22

CESCO DVN : Dahur

W.O. No. SL- 20227

Date 13/02/23

Total Invoice Value (In Words) : Six Hundred and Thirty Two Rupees Only

E&OE

- 1st Copy Original : White
- 2nd Copy Duplicate : Pink
- 3rd Copy Triplicate : Yellow
- 4th Copy Extra : Blue

For Landis+Gyr Limited

Signature