

**ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ**  
**CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED**

**TEST CERTIFICATE**

Date : 15/9/12

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER** as tested good it is Sealed in the **MT** section having the Meter & Seal details below.

**Meter Details :**

Make: **EL SEWEDY**

Model: **EM101-1**

Class: **1**

1P,2 W

3200Imp/kWh

50 Hz.

240V

5-30A

Meter SI.No. : 11039020

Initial Reading 000 00 2 (CkWh)

135 (EL-S White Plastic)

Numbered 154 1030 (CESC G & W Plastic)

TERMINAL PORT: Numbered round (CESC G & W Plastic)

TEST KHN: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg.(Ele.),  
 LT Rating Sub-division

CESC Division : 135

W.O. No. : 55-13102 Date : 28/9/12

Total Invoice Value (In Words) :

CGST@9%

710/-

SGST@9%

710/-

GRAND TOTAL

9510/-

**MANUFACTURER'S WARRANTY**

E & O E 1<sup>st</sup> Copy Original : 2<sup>nd</sup> Copy Duplicate : 3<sup>rd</sup> Copy Triplicate :

We confirm that the EL-Sewedy Electrometer India Pvt. Ltd. meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) Years from the date of sale. If within this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. Our warranty however, shall not cover or extend to damage due to misuse/handling tampering/accident of negligence on part of the consumer, normal wear and tear of the moving parts and burnt meters of which shall be sole judge. The warranty is valid for : 1. The Meters installed correctly. 2. The Meters mounted indoor. 3. In case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain. 4. The meters maintained in a proper way. 5. The meters maintained in a proper way. 6. The meters store in a dry and protected place. The meters will be supplied in Factory and CESCO MT division sealed condition. Our above warranty clause will not be applicable once the factory seal/CESCO MT seal is broken/tampered.

For EL-Sewedy Electrometer India Pvt. Ltd.

Signatory