

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 25/10/23

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER** INDIA Pvt. Ltd. was tested good it is Sealed in the MT section having the Meter & Seal details as below.

Meter Details :

Make : **EL SEWEDY** 1P,2 W 240V
Type : **EM101-1** 3200Imp/kWh 5-30A
: 1 50 Hz.

SI.No. : 11048905 Initial Reading 000 00.2 (CkWh)

provided to Main Cover

25 (EL-S White Plastic)

Numbered round (CESC G & W Plastic)

AL PORT: Numbered round (CESC G & W Plastic)

T KHN: Numbered round (CESC G & W Plastic)

D. S. S. S.
JE/AE/Asst. Executive Engg. (Ele.),
LT Rating Sub-division

CESC Division		CGST@9%		71 01	
W.O. No. 13174		SGST@9%		71 01	
Date 25/10/23		GRAND TOTAL		93 01	
Total Invoice Value (In Words) :					