

Temporary power supply

(ಮಂಡಳಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

* ಅವರಣದ ಮಾದರಿ

ಪಾಯಿಂಟು/ಮೊಟಾರುಗಳ ಒಟ್ಟು ಸಂಖ್ಯೆ

ಒಟ್ಟು ಸಂಪರ್ಕ ಪ್ರಮಾಣ

ಪೇಜ್ ಮೇಲೆ ಸಂಪರ್ಕ ಪ್ರಮಾಣ ಅ)

ಆ)

ಇ)

ವಿತರಣಾ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರುಗಳು :

ಇರುವ ಸ್ಥಳ

ಪೊಲ್ಟೀಜ್ ಪ್ರಮಾಣ

ಸಾಮರ್ಥ್ಯ

ಸಂಪರ್ಕ ಪ್ರಮಾಣ

ಮಾಪಕ :

ಮಾದರಿ ಮತ್ತು ತಯಾರಿಕೆ

ಸಾಮರ್ಥ್ಯ

ಪ್ರಾರಂಭದ ರೀಡಿಂಗ್

ಇತರೆ :

ಮಾಪಕವನ್ನು ಸರಿಯಾಗಿ ಮೊಹರು ಮಾಡಿದೆಯೆ

ಮಾಪಕ ಟರ್ಮಿನಲ್ ಕವರನ್ನು ಮೊಹರು ಮಾಡಿದೆಯೆ

ಕಟ್ ಔಟ್ ಮೊಹರು ಮಾಡಿದೆಯೆ

ಈ ಇನ್‌ಸ್ಟಲೇಷನ್ ವೈರಿಂಗ್

ನಿಯಮಗಳಿಗೆ ಅನುಸಾರವಾಗಿದೆಯೆ

ಯಾವುದಾದರೂ ನ್ಯೂನತೆಗಳನ್ನು ಗಮನಿಸಲಾಗಿಯೆ

ಮಾಪಕ ಅವರ್ತವನ್ನು ಪರೀಕ್ಷಿಸಲಾಗಿದೆಯೆ

ಸರಿಯಾಗಿದೆಯೆ ಮತ್ತು ಅದು

ಮಾಪಕ ಕಾರ್ಡನ್ನು ಹಾಕಿದೆಯೆ

LT

1KL

ರಾಜೀವ್

25/1/20

11KL/4330

DTG - 43561

EL - Sewerdy

SL-NO - 110 45414

TR - 00000.5

44

140

44

ಆರ್.ಆರ್.ನಂ. ಬರೆಯಲಾಗಿದೆಯೆ

ಮಾಪಕದಲ್ಲಿ ಹಾಳೆಯನ್ನು ಇಡಲಾಗಿದೆಯೆ

ಪುಸ್ತಕ ಸಂಖ್ಯೆ

ಇನ್‌ಸ್ಟಲೇಷನ್ ಸಂಖ್ಯೆ

ಸಂಪರ್ಕ ದಿನಾಂಕ

ಸಂಪರ್ಕ

ಹೊಸ

ಟ್ರಾಪಿಂಗ್

ದೂರವಾಣಿ ಕ್ಯಾಪಿಂಗ್

ಮಾಪಕ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ

ಈ ಆರ್.ಆರ್. ಸಂಖ್ಯೆಯ ನಂತರದ್ದು

ಮಾಪಕ ಓದುವ ದಿನಾಂಕ

ಸೇವಾ ಮಾರ್ಗ

ಕಂಡಕ್ಟರ್ ಸಿಯು/ಎ

ಕೇಬಲ್ ಡಬ್ಲ್ಯೂ.ಪಿ/ವಿಐಆರ್/ಸಿಟಿಎನ್

ಕೊಳವೆ

ಅರ್ಥಿಂಗ್

ಎರಿಯಲ್ ಪ್ಯೂಸ್

ಕಟ್ ಔಟ್

ಸಂಪರ್ಕ ಸೇವೆ ದೂರ

ಪರೀಕ್ಷೆ :

ಫೇಸುಗಳು ಮಧ್ಯೆ

ಫೇಸ್‌ನಿಂದ ನೆಲಕ್ಕೆ

ನ್ಯೂಟ್ರಲ್‌ನಿಂದ ನೆಲಕ್ಕೆ

44

HTPS-225
29/1/20

Tps

YL-61

Temporary
power
Supply

15mL

OK

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ, ನಾನು ಸ್ಥಾವರವನ್ನು ಪರೀಕ್ಷಿಸಿದ್ದೇನೆ ಮತ್ತು ರೇಟಿಡ್ ಮಾಡಿದ್ದೇನೆ

ಹೋಗೇರೆ
(ಗ್ರಾಹಕರ ಸಹಿ)

ಲಂಚು
(ಗುತ್ತಿಗೆದಾರರ/ತಾಂತ್ರಿಕ ಸಲಹೆಗಾರರ ಸಹಿ)

ಇಂಜಿನಿಯರು

ವಾಸದ ಮನೆ, ಅಂಗಡಿ, ಕಛೇರಿ, ಹೋಟೆಲು, ರೆಸ್ಟೋರೆಂಟ್, ಚಲನಚಿತ್ರ ಮಂದಿರ, ಆಸ್ಪತ್ರೆ, ಧಾರ್ಮಿಕ, ಶೈಕ್ಷಣಿಕ, ಕೈಗಾರಿಕೆ, (ವಿವರಿಸಿ) ಕೃಷಿ
ಪಿಂಗ್, ಇತರ ಪಂಪಿಂಗ್, (ವಿವರಿಸಿ) ಗೃಹ ಕೈಗಾರಿಕೆ, (ವಿವರಿಸಿ) ಇದರಲ್ಲಿ ಯಾವುದು ಎಂಬುದನ್ನು ತಿಳಿಸಿ.

ಅಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ
AMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date : 8/12/22

This is to Certify that the Meter received from **EL SEWEDY ELECTRO METER**
DIA Pvt. Ltd. was tested good it is Sealed in the **MT** section having the Met
Seal details as below.

Meter Details :

Make : **EL SEWEDY**

Type : **EM101-1**

Class : **1**

1P,2 W

3200Imp/kWh

50 Hz.

240V

5-30A

Meter Sl.No. : 11045414 Initial Reading 000 (CkWh)

Seal Provided to Main Cover

- 1) A 10 2946 (EL-S White Plastic)
- 2) Numbered A 668 883 (CESC G & W Plastic)
- 3) OPTICAL PORT: Numbered round (CESC G & W Plastic)
- 4) RESET KHNB: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg. (Ele)
LT Rating Sub-division

10

TAX INVOICE

EL - Sewedy Electrometer India Pvt. Ltd.

Address:
Sewedy Electro meter India Pvt. Ltd.
Energy Meter Retail Outlet, MPL Compound, Shri Harsha Road,
Executive Engineer CESC, N.R. Mohalla Division, MYSORE-570001
Sewedy Electrometer India Pvt. Ltd.
No.: C-138, Sector-63 Noida-201301 UP, INDIA
IN NO.: 09AACCE0583H1ZO

Branch Office Address .

EL-Sewedy Electro meter India Pvt. Ltd.
Energy Meter Retail Outlet, O/o Executive Engineer,
O&M Division, CESC, HN Pura Road, Near
KSRTC Bus stand, HASSAN - 573201.

Customer Name Yogesh
Address 560 Hanliyaappa
Palahanka
Hassan
IN:

BILL No.: **HSN/23/** 5959DATE: 16/12/23

GSTIN : 29AACCE0583H1ZM

Description of Goods/ Service	Quantity (Nos.)	Rate Per Pc (Rs.)	Value Amount	
			Rs.	P.
IN Code : 90283090 Single / Three Phase / LTCT Static Energy Meter Nos. <u>11045414</u>	1	788-99	788	99
Division <u>Hassan</u>	CGST@ 9%		91	01
No. <u>SS 15186</u> Date <u>16/12/23</u>	SGST@ 9%		91	01
Grand Invoice Value (In Words) :		GRAND TOTAL		981 01

MANUFACTURER'S WARRANTY

E & O E 1st Copy Original 2nd Copy Duplicate 3rd Copy Triplicate

Warranty: The EL-Sewedy Electrometer India Pvt. Ltd. meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) Years from the date of purchase. However, shall not cover or extend to damage due to misuse/mishandling/tampering/accident of negligence on part of the consumer, normal wear and tear of the meters installed correctly. 2. The Meters mounted indoor. 3. In case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain. 4. The meters maintained in a proper way. 5. The meters store in a dry and protected place. The meters will be supplied in sealed condition. Our address: EL-Sewedy Electrometer India Pvt. Ltd., Energy Meter Retail Outlet, MPL Compound, Shri Harsha Road, Executive Engineer CESC, N.R. Mohalla Division, MYSORE-570001.

For EL-Sewedy Electrometer India Pvt. Ltd.

Signatory