

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date: 1/02/24

This is to Certify that the Meter received from M/s Linkwell Telesystems was tested good it is Sealed in the MT section having the Meter & Seal details as below.

Meter Details :

A - 50186
16-4-24

Linkwell Telesystems 1P, 2W 240V (L-N) 5-30A
36SM 3200 Imp/kWh 50 Hz Class: 1.0

1225545 Initial Reading. 000000-2 (C kWh)

Seal Provided to Main Cover :

Linkwell Transparency)

Numbered... R-089/085 (CESC G & W Plastic)

OPTICAL PORT: Numbered round (CESC G & W Plastic)

REST KHNB: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg. (Ele.),

LT Rating Sub-division

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ ನಿಯಮಿತ

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED

TEST CERTIFICATE

Date: 1/02/24

This is to Certify that the Meter received from M/s Linkwell Telesystems was tested good it is Sealed in the MT section having the Meter & Seal details as below.

Meter Details :

A - 50187
16-4-24

Make : Linkwell Telesystems 1P, 2W 240V (L-N) 5-30A
Type : 36SM 3200 Imp/kWh 50 Hz Class: 1.0

Sl.No. : 1225546 Initial Reading. 000000-2 (C kWh)

Seal Provided to Main Cover :

1) (Linkwell Transparency)

2) Numbered... R-089/086 (CESC G & W Plastic)

3) OPTICAL PORT: Numbered round (CESC G & W Plastic)

4) REST KHNB: Numbered round (CESC G & W Plastic)

JE/AE/Asst. Executive Engg. (Ele.),
LT Rating Sub-division