

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು

ನಿಗಮನಿಯಮಿತ

[ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ]

ಹೆಚ್.ಟಿ. ರೇಟಿಂಗ್, ಉಪವಿಭಾಗ,

ಚಾಮುಂಡೇಶ್ವರಿ, ಮಂಡ್ಯ-571401

Mob:No : 9448994862



CHAMUNDESHWARI ELECTRICITY SUPPLY
CORPORATION LIMITED
(A Government of Karnataka
Undertaking)
HT Rating, Sub-Division,
CESC, Mandya
Web site: www.cescmysore.org
E-mail ID acehundy@cescmysore.org
htratingmandya@gmail.co.

Company Identity Number (CIN) U40109KA2004SGC035177

No: AEE(E)/HTR/MDY/SRHTT-131/2022-23/ 2897-2899

Date: 31.12.2022

To,

The Asst. Executive Engineer(Ele),
O&M Sub-Division, CESC,
Srirangapatna.

Sir,

I Wish to furnish here with the test results of the following H.T installation.

R.R. No.	Name and Address	CD Contract Demand	Nature of Industry	Reason for Rating	Date of PC Test	Previous Rated on	Date of Present Rating
SRHTT 156	M/s Dilip Build Ltd, Sy No. 227, Bhramapura Village, S.R. Patna Tq.	100 KVA	Construction	Permanent Disconnection	03.06.2020	07.12.22	30.12.22

Seals	Cable Main	CT & PT	T.V.M	T.T.B.	M. Door
As Found	RRA 12677	RRA 12678	RP AJ82551 (TC) 0930486 (RST) 0930487	RRA 13454	RRA 13455
As Left	Released	Released	Released	Released	Released

Name Plate Details:

	Make	Sl. No.	VA	Class	Ratio	Sys voltage
CT	Kalpa	125203/19, 125194/19, 125195/19	2.5	0.2	5/1A	11KV
PT	Kalpa	97567/19, 97652/19, 97703/19	25	0.2	11KV/√3 110V/√3	11KV

Meter Details:

Make: L&T, Type:ER300P, Class:0.2, S.No: 19003099, Volts:3x63.5V, Current:1A,P/U:50,000, 3Φ4W

Reference Standard Used: ZERA MT310, GERMAN Make,0.1 Class Calibrator S.No: 50023828.

Connected C.T.Ratio: 5/1Amps

Connected P.T.Ratio: 11KV/√3

110V/√3

Multiplying Constant: (Kwh.Kvarh.Kvah.MD Kva)X 500

PTsec volts : 61.00, 60.55, 61.20 Volts
C.T. Current : 0.0449, 0.0421, 0.0510 Amps
Watts : 1.58
Rated Kva : 4.205
Rated PF : -0.1885
Phase Seq : Reverse

Accuracy	%Error	Remarks
KWh	0.12	Accuracy is with in limits
KVARH	0.13	Accuracy is with in limits

METER READINGS:

KWH: 000558.06	MD Kva: 0.1098
KVARH(lag): 000038.15	Reset Count: 45
KVARH(lead): 000176.03	Rpf: 0.989
KVAH: 000566.19	CMD Kva: 00004.46

Remarks:- Above said installation inspected for rating of TVM and furnishing FR, since consumer requested for permanent disconnection Vide letter No. AEE(E)/SAE(T)/SRP/2022-23/3560 Date: 29.12.2022 of AEE, S.R. Patna sub division and kindly consider above mentioned reading as FR for further billing.

Yours faithfully,

Assistant Executive Engineer (Ele),
H.T. Rating Sub Division,
CESC, Mandya.

Copy to:

1. The Accounts Officer, Internal Audit, CESC, Pandavapura.
2. M/s Dilip Build Con Ltd, Sy No. 227, BhramapuraVillage, S.R. Patna Tq.
3. O.C/M.F