

Meter Details					
Make of Meter	L&T	Meter Version	NTD19.04	VinPlus Version	TS 232.01
Meter Serial No.	18136661	Meter Type	2,(3ph-4W) HT PT/CT	Meter Location	
Consumer Name		Consumer ID			
Anomaly	A0XXXXXXXXXX000	Collection			
Data Dump Time(PC)	05/04/2023 16:56:41	Data Read Time (Meter)	05/04/2023 15:38:44	Data Read Time (MRI/PC)	05/04/2023 16:08:06
CT Ratio	1	PT Ratio	1		
Association Mode	1,(Meter Reader)	Logical Device Name	LNTM4XXXXXXC5	Manufactured Info	2018
Name Plate Details	HT 63.5V CL 0.2(ACTIVE) 0.2(REACTIVE) Ib-1A				
Utility Name					
CT Rating	1-2A	Category	HT(PT/CT operated)<(CT operated)-C1		

Present Values

Cumulative Energies at		05/04/2023 15:39			
Power ON Time since Reset		0 Years, 4 Days, 12 Hrs, 10 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	313.11	293.61	--	--	--
2	674.06	618.58	--	--	--
3	343.12	314.39	--	--	--
4	661.48	605.37	--	--	--
5	0.00	0	--	--	--
6	0.00	0	--	--	--
7	0.00	0	--	--	--
8	0.00	0	--	--	--
Total	1991.77	1831.95	618.91	376.11	0.96



Schneider Electric India Private Limited

Billing Report

Cumulative MD(MAX of Tariffs)

Fwd.kVA	Fwd.kW
5.9000	5.0200

Consumption from 01/04/2023 00:00 to 05/04/2023 15:39					
Reset Mechanism					
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead	Fwd. AvgPF
1	0.88	0.87	--	--	--
2	1.83	1.76	--	--	--
3	0.84	0.80	--	--	--
4	1.82	1.76	--	--	--
5	0.00	0.00	--	--	--
6	0.00	0.00	--	--	--
7	0.00	0.00	--	--	--
8	0.00	0.00	--	--	--
Total	5.37	5.19	1.10	0.36	0.960

MD Parameter :

TOD	Fwd.kW	Fwd.kVA
1	0.0638	0.0665
TOD MD DateTime	05/04/2023 10:00	05/04/2023 10:00
2	0.0695	0.0733
TOD MD DateTime	03/04/2023 17:00	03/04/2023 17:00
3	0.0636	0.0695
TOD MD DateTime	01/04/2023 18:30	01/04/2023 18:30
4	0.0596	0.0626
TOD MD DateTime	04/04/2023 23:00	04/04/2023 23:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD (0-24hrs)	Fwd.kW	Fwd.kVA
Value	0.0695	0.0733
MD DateTime	03/04/2023 17:00	03/04/2023 17:00



Billing Report

Cumulative energies - Resetwise:

Cumulative energy at		01/04/2023 00:00		Reset No: 1	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 17 Hrs, 36 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	312.23	292.74	--	--	--
2	672.23	616.82	--	--	--
3	342.28	313.59	--	--	--
4	659.66	603.61	--	--	--
5	0	0	--	--	--
6	0	0	--	--	--
7	0	0	--	--	--
8	0	0	--	--	--
Total	1986.4	1826.76	617.81	375.75	0.98
Cumulative energy at		01/03/2023 00:00		Reset No: 2	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 6 Hrs, 53 Mins			
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF
1	305.9	286.47	--	--	--
2	658.43	603.31	--	--	--
3	335.4	306.87	--	--	--
4	646.13	590.38	--	--	--
5	0	0	--	--	--
6	0	0	--	--	--
7	0	0	--	--	--
8	0	0	--	--	--
Total	1945.86	1787.03	612.27	366.47	0.98

Cumulative energy at		01/02/2023 00:00			Reset No: 3	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 10 Hrs, 42 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	299.29	279.93	--	--		--
2	644.89	589.99	--	--		--
3	328.38	299.98	--	--		--
4	631.96	576.46	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1904.52	1746.36	607.42	359.54		0.98
Cumulative energy at		01/01/2023 00:00			Reset No: 4	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 22 Hrs, 32 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	292.22	272.92	--	--		--
2	628.96	574.38	--	--		--
3	320.51	292.28	--	--		--
4	617.52	562.31	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1859.21	1701.89	602.11	348.46		0.98



Billing Report

Cumulative energy at		01/12/2022 00:00			Reset No: 5	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 0 Hrs, 6 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	285.69	266.43	--	--		--
2	613.84	559.58	--	--		--
3	312.82	284.75	--	--		--
4	603.06	548.1	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1815.41	1658.86	596.95	338.76		0.99
Cumulative energy at		01/11/2022 00:00			Reset No: 6	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 9 Hrs, 49 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	279.97	260.74	--	--		--
2	601.17	547.03	--	--		--
3	306.4	278.39	--	--		--
4	591.32	536.47	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1778.86	1622.63	594.51	327.84		0.98

Cumulative energy at		01/10/2022 00:00			Reset No: 7	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 18 Hrs, 58 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	273.41	254.24	--	--		--
2	585.76	531.86	--	--		--
3	299.55	271.64	--	--		--
4	579.12	524.39	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1737.84	1582.13	590.48	316.69		0.89
Cumulative energy at		01/09/2022 00:00			Reset No: 8	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 10 Hrs, 27 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	266.41	247.77	--	--		--
2	569.44	517.24	--	--		--
3	291.14	264.09	--	--		--
4	564.12	511.05	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1691.11	1540.15	574.01	311.94		0.83

Cumulative energy at		01/08/2022 00:00			Reset No: 9	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 1 Hrs, 55 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	260.4	242.45	--	--		--
2	555.03	505.12	--	--		--
3	283.37	257.68	--	--		--
4	550.38	499.73	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1649.18	1504.98	552.86	310.02		0.84
Cumulative energy at		01/07/2022 00:00			Reset No: 10	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 22 Hrs, 42 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	253.74	236.61	--	--		--
2	541.81	493.89	--	--		--
3	276.15	251.66	--	--		--
4	536.66	488.39	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1608.36	1470.55	533.2	306.92		0.87

Cumulative energy at		01/06/2022 00:00			Reset No: 11	Reset Type:
Billing Power ON Time		0 Years, 26 Days, 23 Hrs, 55 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	247.9	231.37	--	--		--
2	527.77	481.75	--	--		--
3	269.57	245.99	--	--		--
4	525.8	478.95	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1571.04	1438.06	517.14	301.73		0.88
Cumulative energy at		01/05/2022 00:00			Reset No: 12	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 9 Hrs, 17 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	244.17	227.9	--	--		--
2	517.57	472.78	--	--		--
3	265.18	242.15	--	--		--
4	518.66	472.68	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1545.58	1415.51	507.65	291.18		0.86

Cumulative energy at		01/04/2022 00:00			Reset No: 13	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 0 Hrs, 37 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	237.81	222.24	--	--		--
2	503.68	460.74	--	--		--
3	258.7	236.6	--	--		--
4	505.12	461.03	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1505.31	1380.61	489.34	287.34		0.91
Cumulative energy at		01/03/2022 00:00			Reset No: 14	Reset Type:
Billing Power ON Time		0 Years, 27 Days, 11 Hrs, 15 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	232.08	216.88	--	--		--
2	492.18	450.21	--	--		--
3	252.32	230.86	--	--		--
4	493.03	450.04	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1469.61	1347.99	477.3	279.58		0.9

Cumulative energy at		01/02/2022 00:00			Reset No: 15	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 12 Hrs, 56 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	227.03	212.16	--	--		--
2	479.98	439.37	--	--		--
3	246.57	225.75	--	--		--
4	482.59	440.53	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1436.17	1317.81	465.34	273.98		0.89
Cumulative energy at		01/01/2022 00:00			Reset No: 16	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 0 Hrs, 46 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	220.36	206.05	--	--		--
2	466.34	427.05	--	--		--
3	238.69	218.86	--	--		--
4	467.93	427.56	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1393.32	1279.52	448.68	269.36		0.87

Cumulative energy at		01/12/2021 00:00			Reset No: 17	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 4 Hrs, 3 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	215.1	201.27	--	--		--
2	454.18	416.37	--	--		--
3	232.58	213.53	--	--		--
4	456.68	417.84	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1358.54	1249.01	434.68	261.32		0.94
Cumulative energy at		01/11/2021 00:00			Reset No: 18	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 12 Hrs, 31 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	210.8	197.12	--	--		--
2	445.28	407.91	--	--		--
3	227.52	208.8	--	--		--
4	446.62	408.42	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1330.22	1222.25	428.17	250.4		0.9



Billing Report

Cumulative energy at		01/10/2021 00:00			Reset No: 19	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 20 Hrs, 55 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	205.21	191.95	--	--		--
2	435.57	399.06	--	--		--
3	221.42	203.33	--	--		--
4	434.21	397.34	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1296.41	1191.68	416.46	242.32		0.96
Cumulative energy at		01/09/2021 00:00			Reset No: 20	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 15 Hrs, 1 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	200.91	187.75	--	--		--
2	426.89	390.75	--	--		--
3	216.42	198.56	--	--		--
4	425.28	388.75	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1269.5	1165.81	411.76	231.69		0.91

Cumulative energy at		01/08/2021 00:00			Reset No: 21	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 0 Hrs, 56 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	195.42	182.58	--	--		--
2	414.03	379.05	--	--		--
3	209.58	192.37	--	--		--
4	412.92	377.44	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1231.95	1131.44	399.52	225.16		0.89
Cumulative energy at		01/07/2021 00:00			Reset No: 22	Reset Type:
Billing Power ON Time		0 Years, 29 Days, 6 Hrs, 14 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	189.44	177.03	--	--		--
2	400.82	367.27	--	--		--
3	201.99	185.73	--	--		--
4	399.67	365.69	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1191.92	1095.72	384.23	220.43		0.92

Cumulative energy at		01/06/2021 00:00			Reset No: 23	Reset Type:
Billing Power ON Time		0 Years, 30 Days, 7 Hrs, 12 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	183.99	171.9	--	--		--
2	389.09	356.35	--	--		--
3	196.12	180.29	--	--		--
4	388.44	355.31	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1157.64	1063.85	374.65	214.61		0.96
Cumulative energy at		01/05/2021 00:00			Reset No: 24	Reset Type:
Billing Power ON Time		0 Years, 28 Days, 7 Hrs, 44 Mins				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVARhLag	Fwd.kVARhLead		Fwd. AvgPF
1	179.66	167.69	--	--		--
2	378.71	346.43	--	--		--
3	190.83	175.2	--	--		--
4	378.73	346	--	--		--
5	0	0	--	--		--
6	0	0	--	--		--
7	0	0	--	--		--
8	0	0	--	--		--
Total	1127.93	1035.32	369.84	201.35		0.91

Consumption - Resetwise

Reset No		1				
Consumption from		01/03/2023 00:00 to 01/04/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.33	6.27	--	--	--	
2	13.80	13.51	--	--	--	
3	6.88	6.72	--	--	--	
4	13.53	13.23	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	40.54	39.73	5.54	9.28	0.980	
Reset No		2				
Consumption from		01/02/2023 00:00 to 01/03/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.61	6.54	--	--	--	
2	13.54	13.32	--	--	--	
3	7.02	6.89	--	--	--	
4	14.17	13.92	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	41.34	40.67	4.85	6.93	0.980	

Reset No		3				
Consumption from		01/01/2023 00:00 to 01/02/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	7.07	7.01	--	--	--	
2	15.93	15.61	--	--	--	
3	7.87	7.70	--	--	--	
4	14.44	14.15	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	45.31	44.47	5.31	11.08	0.980	
Reset No		4				
Consumption from		01/12/2022 00:00 to 01/01/2023 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.53	6.49	--	--	--	
2	15.12	14.80	--	--	--	
3	7.69	7.53	--	--	--	
4	14.46	14.21	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	43.80	43.03	5.16	9.70	0.980	

Reset No		5				
Consumption from		01/11/2022 00:00 to 01/12/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.72	5.69	--	--	--	
2	12.67	12.55	--	--	--	
3	6.42	6.36	--	--	--	
4	11.74	11.63	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	36.55	36.23	2.44	10.92	0.990	
Reset No		6				
Consumption from		01/10/2022 00:00 to 01/11/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.56	6.50	--	--	--	
2	15.41	15.17	--	--	--	
3	6.85	6.75	--	--	--	
4	12.20	12.08	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	41.02	40.50	4.03	11.15	0.980	

Reset No		7				
Consumption from		01/09/2022 00:00 to 01/10/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	7.00	6.47	--	--	--	
2	16.32	14.62	--	--	--	
3	8.41	7.55	--	--	--	
4	15.00	13.34	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	46.73	41.98	16.47	4.75	0.890	
Reset No		8				
Consumption from		01/08/2022 00:00 to 01/09/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.01	5.32	--	--	--	
2	14.41	12.12	--	--	--	
3	7.77	6.41	--	--	--	
4	13.74	11.32	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	41.93	35.17	21.15	1.92	0.830	

Reset No		9				
Consumption from		01/07/2022 00:00 to 01/08/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.66	5.84	--	--	--	
2	13.22	11.23	--	--	--	
3	7.22	6.02	--	--	--	
4	13.72	11.34	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	40.82	34.43	19.66	3.10	0.840	
Reset No		10				
Consumption from		01/06/2022 00:00 to 01/07/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.84	5.24	--	--	--	
2	14.04	12.14	--	--	--	
3	6.58	5.67	--	--	--	
4	10.86	9.44	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	37.32	32.49	16.06	5.19	0.870	

Reset No		11				
Consumption from		01/05/2022 00:00 to 01/06/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	3.73	3.47	--	--	--	
2	10.20	8.97	--	--	--	
3	4.39	3.84	--	--	--	
4	7.14	6.27	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	25.46	22.55	9.49	10.55	0.880	
Reset No		12				
Consumption from		01/04/2022 00:00 to 01/05/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.36	5.66	--	--	--	
2	13.89	12.04	--	--	--	
3	6.48	5.55	--	--	--	
4	13.54	11.65	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	40.27	34.90	18.31	3.84	0.860	

Reset No		13				
Consumption from		01/03/2022 00:00 to 01/04/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.73	5.36	--	--	--	
2	11.50	10.53	--	--	--	
3	6.38	5.74	--	--	--	
4	12.09	10.99	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	35.70	32.62	12.04	7.76	0.910	
Reset No		14				
Consumption from		01/02/2022 00:00 to 01/03/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.05	4.72	--	--	--	
2	12.20	10.84	--	--	--	
3	5.75	5.11	--	--	--	
4	10.44	9.51	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	33.44	30.18	11.96	5.60	0.900	

Reset No		15				
Consumption from		01/01/2022 00:00 to 01/02/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	6.67	6.11	--	--	--	
2	13.64	12.32	--	--	--	
3	7.88	6.89	--	--	--	
4	14.66	12.97	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	42.85	38.29	16.66	4.62	0.890	
Reset No		16				
Consumption from		01/12/2021 00:00 to 01/01/2022 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.26	4.78	--	--	--	
2	12.16	10.68	--	--	--	
3	6.11	5.33	--	--	--	
4	11.25	9.72	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	34.78	30.51	14.00	8.04	0.870	

Reset No		17				
Consumption from		01/11/2021 00:00 to 01/12/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	4.30	4.15	--	--	--	
2	8.90	8.46	--	--	--	
3	5.06	4.73	--	--	--	
4	10.06	9.42	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	28.32	26.76	6.51	10.92	0.940	
Reset No		18				
Consumption from		01/10/2021 00:00 to 01/11/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.59	5.17	--	--	--	
2	9.71	8.85	--	--	--	
3	6.10	5.47	--	--	--	
4	12.41	11.08	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	33.81	30.57	11.71	8.08	0.900	

Reset No		19				
Consumption from		01/09/2021 00:00 to 01/10/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	4.30	4.20	--	--	--	
2	8.68	8.31	--	--	--	
3	5.00	4.77	--	--	--	
4	8.93	8.59	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	26.91	25.87	4.70	10.63	0.960	
Reset No		20				
Consumption from		01/08/2021 00:00 to 01/09/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.49	5.17	--	--	--	
2	12.86	11.70	--	--	--	
3	6.84	6.19	--	--	--	
4	12.36	11.31	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	37.55	34.37	12.24	6.53	0.910	

Reset No		21				
Consumption from		01/07/2021 00:00 to 01/08/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.98	5.55	--	--	--	
2	13.21	11.78	--	--	--	
3	7.59	6.64	--	--	--	
4	13.25	11.75	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	40.03	35.72	15.29	4.73	0.890	
Reset No		22				
Consumption from		01/06/2021 00:00 to 01/07/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	5.45	5.13	--	--	--	
2	11.73	10.92	--	--	--	
3	5.87	5.44	--	--	--	
4	11.23	10.38	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	34.28	31.87	9.58	5.82	0.920	

Reset No		23				
Consumption from		01/05/2021 00:00 to 01/06/2021 00:00				
TOD	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	Fwd. AvgPF	
1	4.33	4.21	--	--	--	
2	10.38	9.92	--	--	--	
3	5.29	5.09	--	--	--	
4	9.71	9.31	--	--	--	
5	0.00	0.00	--	--	--	
6	0.00	0.00	--	--	--	
7	0.00	0.00	--	--	--	
8	0.00	0.00	--	--	--	
Total	29.71	28.53	4.81	13.26	0.960	

Maximum Demand (MD) - Resetwise

Reset No : 1		
MDTOD at	01/04/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0913	0.0938
TOD MD DateTime	19/03/2023 09:00	19/03/2023 09:00
2	0.1068	0.1127
TOD MD DateTime	19/03/2023 17:00	19/03/2023 17:00
3	0.0900	0.0942
TOD MD DateTime	19/03/2023 18:30	22/03/2023 20:00
4	0.0971	0.1041
TOD MD DateTime	20/03/2023 00:30	20/03/2023 00:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1068	0.1127
MD DateTime	19/03/2023 17:00	19/03/2023 17:00

Reset No : 2		
MDTOD at	01/03/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0831	0.0841
TOD MD DateTime	13/02/2023 07:30	26/02/2023 10:00
2	0.0959	0.0996
TOD MD DateTime	22/02/2023 17:30	22/02/2023 17:30
3	0.0905	0.0950
TOD MD DateTime	09/02/2023 18:30	09/02/2023 18:30
4	0.0912	0.0971
TOD MD DateTime	24/02/2023 01:30	24/02/2023 01:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0959	0.0996
MD DateTime	22/02/2023 17:30	22/02/2023 17:30

Reset No : 3		
MDTOD at	01/02/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.1022	0.1048
TOD MD DateTime	31/01/2023 09:30	31/01/2023 09:30
2	0.0997	0.1075
TOD MD DateTime	27/01/2023 15:30	27/01/2023 15:30
3	0.0909	0.0946
TOD MD DateTime	19/01/2023 18:30	19/01/2023 18:30
4	0.0874	0.0953
TOD MD DateTime	19/01/2023 06:00	03/01/2023 01:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1022	0.1075
MD DateTime	31/01/2023 09:30	27/01/2023 15:30

Reset No : 4		
MDTOD at	01/01/2023 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0945	0.0986
TOD MD DateTime	08/12/2022 09:30	08/12/2022 09:30
2	0.0988	0.1134
TOD MD DateTime	07/12/2022 18:00	08/12/2022 15:00
3	0.0906	0.1029
TOD MD DateTime	08/12/2022 19:30	08/12/2022 19:30
4	0.0864	0.0908
TOD MD DateTime	13/12/2022 00:00	13/12/2022 00:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0988	0.1134
MD DateTime	07/12/2022 18:00	08/12/2022 15:00

Reset No : 5		
MDTOD at	01/12/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0858	0.0869
TOD MD DateTime	15/11/2022 08:00	15/11/2022 08:00
2	0.0934	0.0993
TOD MD DateTime	03/11/2022 13:30	03/11/2022 13:30
3	0.0853	0.0874
TOD MD DateTime	15/11/2022 18:30	15/11/2022 18:30
4	0.0828	0.0908
TOD MD DateTime	25/11/2022 00:00	05/11/2022 03:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0934	0.0993
MD DateTime	03/11/2022 13:30	03/11/2022 13:30

Reset No : 6		
MDTOD at	01/11/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0956	0.0983
TOD MD DateTime	28/10/2022 09:00	28/10/2022 09:00
2	0.1073	0.1117
TOD MD DateTime	18/10/2022 11:30	18/10/2022 11:30
3	0.0949	0.0983
TOD MD DateTime	07/10/2022 19:00	07/10/2022 19:00
4	0.0856	0.0879
TOD MD DateTime	18/10/2022 22:30	18/10/2022 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1073	0.1117
MD DateTime	18/10/2022 11:30	18/10/2022 11:30



Schneider Electric India Private Limited

Billing Report

Reset No : 7		
MDTOD at	01/10/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0974	0.1005
TOD MD DateTime	29/09/2022 10:00	29/09/2022 10:00
2	0.0958	0.1213
TOD MD DateTime	29/09/2022 17:00	03/09/2022 17:30
3	0.0971	0.1192
TOD MD DateTime	03/09/2022 20:30	03/09/2022 20:30
4	0.0878	0.1106
TOD MD DateTime	03/09/2022 23:00	03/09/2022 23:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0974	0.1213
MD DateTime	29/09/2022 10:00	03/09/2022 17:30

Reset No : 8		
MDTOD at	01/09/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0877	0.1064
TOD MD DateTime	23/08/2022 10:00	23/08/2022 10:00
2	0.0969	0.1177
TOD MD DateTime	21/08/2022 17:30	24/08/2022 13:00
3	0.0922	0.1128
TOD MD DateTime	23/08/2022 20:30	24/08/2022 19:00
4	0.0910	0.1210
TOD MD DateTime	23/08/2022 02:30	23/08/2022 02:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0969	0.1210
MD DateTime	21/08/2022 17:30	23/08/2022 02:30

Reset No : 9		
MDTOD at	01/08/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0744	0.0915
TOD MD DateTime	14/07/2022 10:00	11/07/2022 07:30
2	0.0831	0.1016
TOD MD DateTime	17/07/2022 13:00	05/07/2022 12:30
3	0.0811	0.1090
TOD MD DateTime	27/07/2022 21:00	27/07/2022 20:00
4	0.0735	0.1012
TOD MD DateTime	20/07/2022 01:30	20/07/2022 01:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0831	0.1090
MD DateTime	17/07/2022 13:00	27/07/2022 20:00

Reset No : 10		
MDTOD at	01/07/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0773	0.0944
TOD MD DateTime	13/06/2022 10:00	13/06/2022 10:00
2	0.0875	0.1148
TOD MD DateTime	11/06/2022 12:00	11/06/2022 12:00
3	0.0756	0.0988
TOD MD DateTime	30/06/2022 19:30	21/06/2022 18:30
4	0.0698	0.0919
TOD MD DateTime	22/06/2022 05:30	22/06/2022 05:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0875	0.1148
MD DateTime	11/06/2022 12:00	11/06/2022 12:00

Reset No : 11		
MDTOD at	01/06/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0716	0.0846
TOD MD DateTime	08/05/2022 09:00	08/05/2022 09:00
2	0.0840	0.0999
TOD MD DateTime	09/05/2022 16:00	09/05/2022 16:00
3	0.0876	0.1084
TOD MD DateTime	09/05/2022 19:00	09/05/2022 19:00
4	0.0696	0.0916
TOD MD DateTime	08/05/2022 05:00	08/05/2022 05:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0876	0.1084
MD DateTime	09/05/2022 19:00	09/05/2022 19:00

Reset No : 12		
MDTOD at	01/05/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0830	0.0999
TOD MD DateTime	12/04/2022 10:00	19/04/2022 06:30
2	0.0920	0.1098
TOD MD DateTime	22/04/2022 16:00	22/04/2022 16:00
3	0.0887	0.1070
TOD MD DateTime	07/04/2022 19:00	07/04/2022 19:00
4	0.0751	0.0944
TOD MD DateTime	19/04/2022 05:00	19/04/2022 05:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0920	0.1098
MD DateTime	22/04/2022 16:00	22/04/2022 16:00



Schneider Electric India Private Limited

Billing Report

Reset No : 13		
MDTOD at	01/04/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0806	0.0934
TOD MD DateTime	28/03/2022 08:00	06/03/2022 06:30
2	0.0819	0.1096
TOD MD DateTime	23/03/2022 17:30	01/03/2022 14:00
3	0.0762	0.0970
TOD MD DateTime	30/03/2022 20:30	13/03/2022 18:30
4	0.0765	0.0927
TOD MD DateTime	29/03/2022 02:30	31/03/2022 01:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0819	0.1096
MD DateTime	23/03/2022 17:30	01/03/2022 14:00

Reset No : 14		
MDTOD at	01/03/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0767	0.0891
TOD MD DateTime	05/02/2022 09:00	05/02/2022 09:00
2	0.0917	0.1140
TOD MD DateTime	07/02/2022 16:00	07/02/2022 16:00
3	0.0759	0.0955
TOD MD DateTime	09/02/2022 18:30	09/02/2022 18:30
4	0.0726	0.0959
TOD MD DateTime	17/02/2022 04:30	17/02/2022 04:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0917	0.1140
MD DateTime	07/02/2022 16:00	07/02/2022 16:00

Reset No : 15		
MDTOD at	01/02/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0854	0.1030
TOD MD DateTime	17/01/2022 10:00	26/01/2022 07:00
2	0.1001	0.1195
TOD MD DateTime	17/01/2022 12:00	17/01/2022 12:00
3	0.0941	0.1112
TOD MD DateTime	17/01/2022 19:30	17/01/2022 19:30
4	0.0830	0.0984
TOD MD DateTime	17/01/2022 23:30	17/01/2022 23:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1001	0.1195
MD DateTime	17/01/2022 12:00	17/01/2022 12:00

Reset No : 16		
MDTOD at	01/01/2022 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0778	0.0964
TOD MD DateTime	08/12/2021 07:00	25/12/2021 07:30
2	0.0819	0.0996
TOD MD DateTime	11/12/2021 16:00	18/12/2021 14:00
3	0.0768	0.1031
TOD MD DateTime	25/12/2021 20:00	25/12/2021 20:00
4	0.0792	0.0983
TOD MD DateTime	08/12/2021 00:00	08/12/2021 00:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0819	0.1031
MD DateTime	11/12/2021 16:00	25/12/2021 20:00

Reset No : 17		
MDTOD at	01/12/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0659	0.0768
TOD MD DateTime	15/11/2021 09:00	15/11/2021 06:30
2	0.0745	0.0967
TOD MD DateTime	14/11/2021 18:00	14/11/2021 18:00
3	0.0737	0.0937
TOD MD DateTime	14/11/2021 19:00	14/11/2021 19:00
4	0.0735	0.0917
TOD MD DateTime	15/11/2021 00:30	15/11/2021 00:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0745	0.0967
MD DateTime	14/11/2021 18:00	14/11/2021 18:00

Reset No : 18		
MDTOD at	01/11/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0752	0.0935
TOD MD DateTime	05/10/2021 10:00	05/10/2021 10:00
2	0.0813	0.0986
TOD MD DateTime	20/10/2021 17:30	20/10/2021 17:30
3	0.0839	0.1011
TOD MD DateTime	20/10/2021 21:30	20/10/2021 21:30
4	0.0802	0.0969
TOD MD DateTime	02/10/2021 22:30	02/10/2021 22:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0839	0.1011
MD DateTime	20/10/2021 21:30	20/10/2021 21:30

Reset No : 19		
MDTOD at	01/10/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0694	0.0829
TOD MD DateTime	30/09/2021 07:00	30/09/2021 07:00
2	0.0689	0.0791
TOD MD DateTime	28/09/2021 15:30	28/09/2021 18:00
3	0.0753	0.0982
TOD MD DateTime	29/09/2021 21:00	29/09/2021 21:00
4	0.0682	0.0872
TOD MD DateTime	30/09/2021 00:00	30/09/2021 00:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0753	0.0982
MD DateTime	29/09/2021 21:00	29/09/2021 21:00

Reset No : 20		
MDTOD at	01/09/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0815	0.0956
TOD MD DateTime	16/08/2021 09:00	16/08/2021 09:00
2	0.0926	0.1113
TOD MD DateTime	16/08/2021 12:30	16/08/2021 16:00
3	0.0838	0.1019
TOD MD DateTime	04/08/2021 20:00	07/08/2021 19:00
4	0.0774	0.0958
TOD MD DateTime	05/08/2021 00:00	08/08/2021 02:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0926	0.1113
MD DateTime	16/08/2021 12:30	16/08/2021 16:00

Reset No : 21		
MDTOD at	01/08/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0788	0.0925
TOD MD DateTime	21/07/2021 09:30	29/07/2021 10:00
2	0.0836	0.1001
TOD MD DateTime	28/07/2021 12:30	29/07/2021 13:00
3	0.0845	0.1076
TOD MD DateTime	20/07/2021 19:00	03/07/2021 18:30
4	0.0796	0.1019
TOD MD DateTime	30/07/2021 01:30	30/07/2021 01:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0845	0.1076
MD DateTime	20/07/2021 19:00	03/07/2021 18:30



Reset No : 22		
MDTOD at	01/07/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0765	0.0896
TOD MD DateTime	26/06/2021 08:00	20/06/2021 08:30
2	0.0808	0.1002
TOD MD DateTime	19/06/2021 12:30	29/06/2021 16:00
3	0.0762	0.0943
TOD MD DateTime	18/06/2021 22:00	18/06/2021 22:00
4	0.0814	0.1049
TOD MD DateTime	19/06/2021 00:00	20/06/2021 03:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0814	0.1049
MD DateTime	19/06/2021 00:00	20/06/2021 03:00

Reset No : 23		
MDTOD at	01/06/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0771	0.0933
TOD MD DateTime	27/05/2021 09:30	27/05/2021 09:30
2	0.0887	0.1086
TOD MD DateTime	25/05/2021 12:30	27/05/2021 13:00
3	0.0735	0.0886
TOD MD DateTime	27/05/2021 22:00	27/05/2021 22:00
4	0.0788	0.0969
TOD MD DateTime	28/05/2021 00:30	28/05/2021 00:30
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.0887	0.1086
MD DateTime	25/05/2021 12:30	27/05/2021 13:00

Reset No : 24		
MDTOD at	01/05/2021 00:00	
TOD	Fwd.kW	Fwd.kVA
1	0.0838	0.0994
TOD MD DateTime	10/04/2021 08:00	10/04/2021 08:00
2	0.1033	0.1213
TOD MD DateTime	09/04/2021 17:00	09/04/2021 17:00
3	0.1004	0.1168
TOD MD DateTime	09/04/2021 18:30	09/04/2021 18:30
4	0.0851	0.1021
TOD MD DateTime	10/04/2021 06:00	10/04/2021 03:00
5	0.0000	0.0000
6	0.0000	0.0000
7	0.0000	0.0000
8	0.0000	0.0000
MD(0-24hrs)	0.1033	0.1213
MD DateTime	09/04/2021 17:00	09/04/2021 17:00

Cumulative MD (Max of Tariffs) - Resetwise

Reset No	Reset DateTime	Fwd.kVA	Fwd.kW
1	01/04/2023 00:00	5.9000	5.0200
2	01/03/2023 00:00	5.7900	4.9100
3	01/02/2023 00:00	5.6900	4.8100
4	01/01/2023 00:00	5.5800	4.7100
5	01/12/2022 00:00	5.4700	4.6100
6	01/11/2022 00:00	5.3700	4.5200
7	01/10/2022 00:00	5.2600	4.4100
8	01/09/2022 00:00	5.1400	4.3200
9	01/08/2022 00:00	5.0200	4.2200
10	01/07/2022 00:00	4.9100	4.1400
11	01/06/2022 00:00	4.7900	4.0500
12	01/05/2022 00:00	4.6900	3.9600
13	01/04/2022 00:00	4.5800	3.8700
14	01/03/2022 00:00	4.4700	3.7900
15	01/02/2022 00:00	4.3500	3.6900
16	01/01/2022 00:00	4.2300	3.5900
17	01/12/2021 00:00	4.1300	3.5100
18	01/11/2021 00:00	4.0300	3.4400
19	01/10/2021 00:00	3.9300	3.3500
20	01/09/2021 00:00	3.8300	3.2800
21	01/08/2021 00:00	3.7200	3.1900
22	01/07/2021 00:00	3.6100	3.1000
23	01/06/2021 00:00	3.5100	3.0200
24	01/05/2021 00:00	3.4000	2.9300

