

Format - 9A

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು
ನಿಗಮ ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ಎ),
ಬಿ.ಎ.ಸಿ.ನಿ.ನಿ., ನಂಜನಗುಡು ವಿಭಾಗ,
66/11ಕೆ.ವಿ ಎಂ.ಯು.ಎಸ್.ಎಸ್ ಕಾಂಪೌಂಡ್,
ಮೈಸೂರು - ಊಟಿ ರಸ್ತೆ, ಸುಜಾತಪುರಂ,
ನಂಜನಗುಡು - 571302
ಕಛೇರಿ ಫೋನ್ ಸಂಖ್ಯೆ, 08221 - 295688



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Executive Engineer (Ele),
CESC., Nanjanagudu Division,
Near 66/11KV Nanjanagudu MUSS Compoun
Mysore - Ooty Road, Sujathapuram,
Nanjanagudu - 571302
Office Phone Number 08221 - 295688
E-mail ID: eeengd@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: EEE/AEE(O)/AE(T)/F-62/2022-23/ 766-69

Dated: 16 MAY 2023

To,

M/S Mold Tek Packaging Ltd.,
Plot No.94, KIADB Adakanahalli Industrial Area,
Nanjanagudu.

Madam/Sir,

Sub: Certificate of synchronization of your 480kWp SRTPV system reg.

Ref: 1. Application Reg. No 07 Dtd: 19.01.2023.
2. PPA executed date.: 30.01.2023.
3. KERC approval letter No.: dated: 18.08.2021.
4. T.O. approval letter No. 10380 Dated: 06.03.2023.

Synchronization test of Solar Rooftop PV system of 480kWp, installed on the roof of your installation bearing RR No.: HTR-177 has been conducted and your SRTPV system successfully synchronized with the CESC grid at 11KV voltage level on 05.05.2023.

Yours faithfully,

Executive Engineer(Ele)
CESC, Nanjanagudu Division

Copy submitted to:

1. Chief Engineer (Electy), O & M Zone, CESC, Mysuru.
2. General Manager (Commercial), Corporate Office, CESC, Mysuru-570017.
3. Superintending Engineer (Elec), O&M Circle, CESC, Mysuru.
4. Deputy General Manager(EBC), Corporate Office, CESC, Mysuru-570017.
5. Executive Engineer, MT division, Mysuru.

MF/OC

Note: The file along with all the documents is to be sent to revenue section for billing purpose.