

Format-6B CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED, Mysore
(Government of Karnataka Undertaking)Office of the AEE,
O&M Sub division....

No. Date:

OFFICIAL MEMORANDUM**Sub:** Inspection of installation up to 10kWp of Solar Rooftop Photovoltaic Generating System on NET METERING BASIS with a capacity of....Kwp and approval for commissioning.**Ref:** 1. Corporate office, CESC letter

Dated:

2. PPA Dated:

3. Ltr No.: dtd: of work completion report submitted jointly by

Smt/Sri(Namer of Applicant) *A.S. Jayakumar*Under Rule No. 47-A of I.E Rules 1956, Approval is hereby accorded to commissioning of the Solar Rooftop Photovoltaic Generating System with a capacity of *0.2* KwpSingle phase/ Three-phase/HT of Smt/Sri *A.S. Jayakumar, Valagerehalli*(Name and address) installed in the installation bearing RR No.: *MD 16454*

This approval is subject to the following condition:

The consumer of the installation shall ensure that at any point of time there should not be any reverse power flow from the SRTPV plant when there is no power supply in the CESC grid.

Details of Equipments**Solar PV module**

1. Make : *Kotak vsta private limited*
- ii. Capacity : *2 Kwp*
- III. Serial No. : *Y-20038/39/45/74/75/81*
4-14745 & Y-15539.

2. Inverter


- I. Make : *GROWATT-2000*
- II. Capacity : *2 KVA*
- III. Serial No. : *A71618004*

3. Cable Size:

- I. DC : *4 sq mm, 2 core*
- II. AC : *4 sq mm, 2 core.*

4. Bi-directional Energy Meter

- I. Make : *SECURE*
- II. Type : *E1C101*
- III. Capacity : *(5-30) A*
- iv. Serial No. : *Y0135203*


AEE, O&M sub division
CESC, Mysore

P.T.O.