

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED, Mysore
(Government of Karnataka Undertaking)

Office of the AEE,
O&M Sub division....

No. Date: 1093 A 6/8/2010

OFFICIAL MEMORANDUM

Sub: Inspection of installation upto 10kWp of Solar Rooftop Photovoltaic Generating System with a capacity of 30kWp and approval for commissioning.

Ref: 1. Corporate office, CESC letter Dated:
2. Ltr No.: dtd: of work completion report from Smt/ Sri and Syatem installer

Under Rule No. 47-A of I.E Rules 1956, Approval is hereby accorded to commission the Solar Rooftop Photovoltaic Generating System with a capacity of 30 Kwp Single phase/ Three phase of Smt/ Sri K. H. Ravish
(Name and address) installed in the installation bearing RR No.: M.P. 2368

This approval is subject to the following condition:

The consumer of the installation shall ensure that at any point of time the Solar supply should not feedback into the grid when CESC grid supply is off.

Details of Equipments

1. **Solar PV module**
 - i. Make : ADANI
 - ii. Capacity : 375 WP
 - iii. Serial No. : Enclosed.
2. **Inverter**
 - i. Make : Good 100
 - ii. Capacity : 30 KVA
 - iii. Serial No. : 9030KMTU 19 BW 0027.
3. **Cable Size:**
 - i. DC : Poly cab
 - ii. AC : Poly cab.
4. **Bi-directional Energy Meter**
 - i. Make : SECURE
 - ii. Type : Three Ph
 - iii. Capacity : X 1319891
 - iv. Serial No. : [Signature]

CESC, Mysore

AEE, O&M sub division

[Signature]
P.T.O