

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED, Mysore
(Government of Karnataka Undertaking)

Office of the AEE,
O&M Sub division....

No. Date:

OFFICIAL MEMORANDUM

Sub: Inspection of installation upto 10kWp of Solar Rooftop Photovoltaic Generating System with a capacity of....Kwp and approval for commissioning.

Ref: 1. Corporate office, CESC letter Dated:
2. Ltr No.: dtd: of work completion report from Smt/ Sri and Syatem installer

Under Rule No. 47-A of I.E Rules 1956, Approval is hereby accorded to commission the Solar Rooftop Photovoltaic Generating System with a capacity of.....30 Kwp Single phase/ Three phase of Smt/Sri Rajesh KB (Name and address) installed in the installation bearing RR No.: MP 2589

This approval is subject to the following condition:

The consumer of the installation shall ensure that at any point of time the Solar supply should not feedback into the grid when CESC grid supply is off.

Details of Equipments1. **Solar PV module**

- i. Make
- ii. Capacity
- iii. Serial No.

: LONGI
: 455WP
: AS BEEN ENCLOSED

2. **Inverter**

- i. Make
- ii. Capacity
- iii. Serial No.

: GOODWE
: 30kW
: 9030kmtu20A 20090

3. **Cable Size:**

- i. DC
- ii. AC

10sqmm

4. **Bi-directional Energy Meter**

- i. Make
- ii. Type
- iii. Capacity
- iv. Serial No.

SECURE

X1619155 X1619156
ESM (ELECTRO STATIC METER)

AEE, O&M sub division -

CESC, Mysore

P.T.O