



Format - 9A

CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Executive Engineer (Ele),
CESC., Nanjanagudu Division,
Near 66/11KV Nanjanagudu MUSS Compound
- Mysore - Ooty Road, Sujathapuram,
Nanjanagudu - 571302
Office Phone Number 08221 - 295688
E-mail ID: eeengd@cescmysore.org



ಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು
ಮ ನಿಯಮಿತ
ರಾಜಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ),
ವಿ.ಸ.ನಿ.ನಿ., ನಂಜನಗೂಡು ವಿಭಾಗ,
/11ಕೆ.ವಿ ಎಂ.ಯೂ.ಎಸ್.ಎಸ್ ಕಾಂಪೌಂಡ್,
ಸೂರು - ಊಟಿ ರಸ್ತೆ, ಸುಜಾತಪುರಂ,
ಜನಗೂಡು - 571302

ಫೋನ್ ಸಂಖ್ಯೆ 08221 - 295688

Company Identity Number[CIN]:- U40109KA2004SGC035177

EE/AEE(O)/AE(T)/F-62/2022-23/೨೫೧೩-೧೪

Dated: 01/08/2022

S BACARDI India Pvt. Ltd.,
rd K.M Stone, Chamarajanagar road,
anjanagudu

am/Sir,

Sub: Certificate of synchronization of your 300kW SRTPV system reg.

Ref: 1. Application Reg. No 31 Dtd: 15.03.2022.
2. PPA executed date.: 04.05.2022.
3. KERC approval letter No.: dated: 18.08.2021.
4. T.O. approval letter No. 1451 Dated: 20.06.2022.

Synchronization test of Solar Rooftop PV system of 300kWp, installed on
roof of your installation bearing RR No.: NHT-35 has been conducted and your
PV system successfully synchronized with the CESC grid at 11KV voltage level on
07.2022.

Yours faithfully,

Executive Engineer(Ele)
CESC, Nanjanagudu Division

Copy submitted to:

1. Chief Engineer (Electy), O & M Zone, CESC, Mysuru.
2. General Manager (Commercial), Corporate Office, CESC, Mysuru-570017.
3. Superintending Engineer (Elec), O&M Circle, CESC, Mysuru.
4. Deputy General Manager(EBC), Corporate Office, CESC, Mysuru-570017.
5. Executive Engineer, O & M Division, Nanjanagudu, CESC.
6. Executive Engineer, MT division, Mysuru.

MF/OC

Note: The file along with all the documents is to be sent to revenue section for billing
purpose.

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ.29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿನ್ನಕಲ್, ಮೈಸೂರು-570017.
Registered Office: Corporate office, #29, Vijayanagara, 2nd Stage, Hinakal, Mysore-570017.